

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KO908		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner HORLAK, STUART						Phone #		1. Well Location				Fire # (if avail.)					
Mailing Address 1380 HOMESTEAD CT						Town of RICHFIELD											
City RICHFIELD						State WI		Zip Code 53076									
County Washington		Co. Permit #		Notification #		Completed 12-02-1995		Subdivision Name PARKVIEW ESTATES				Lot # 7					
Well Constructor (Business Name) HOWARD H GROTH						Lic. # 651		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.2395 °N -88.253 °W					
Address W69 N949 WASHINGTON CEDARBURG WI 53012						Well Plan Approval #		SE SW		Section 16		Township 9 N					
								Range 19 E									
Hicap Permanent Well #						Common Well #		Specific Capacity 1.5		2. Well Type New Well							
Reason for replaced or reconstructed well ?						WATER											
3. Well serves 1 # of Private, potable						Hicap Well ? No		Hicap Property ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes						Hicap Potable ?											
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.) 6		From (ft.) Surface		To (ft.) 211		Upper Enlarged Drillhole				Lower Open Bedrock							
						Rotary - Mud Circulation											
						Rotary - Air											
						Rotary - Air & Foam											
						Drill-Through Casing Hammer											
						Reverse Rotary											
						Cable-tool Bit ___ in. dia...											
						Dual Rotary											
						Temp. Outer Casing ___ in. dia											
						Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
Q		X		C		GRAVEL SAND CLAY CAVING				Surface		70					
		C		S		SANDY CLAY				70		90					
		C				CLAY				90		105					
		S				SAND				105		125					
		C		S		SANDY CLAY				125		170					
		S				SAND				170		200					
		G				GRAVEL				200		211					
6. Casing, Liner, Screen																	
Dia. (in.) 6		Material, Weight, Specification 1897 LB ASTMA53PE IPSCO				From (ft.) Surface		To (ft.) 211		9. Static Water Level							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		11. Well Is							
Method										80 ft. below ground surface							
										10. Pump Test							
										Developed ? Yes							
										Disinfected ? Yes							
										Capped ? Yes							
7. Grout or Other Sealing Material										12. Notified Owner of need to fill & seal ?							
										Filled & Sealed Well(s) as needed?							
										13. Constructor / Supervisory Driller				Lic #		Date Signed	
										HG						01-03-1996	
										Drill Rig Operator				Lic or Reg #		Date Signed	
MH						01-03-1996											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		140	Wastewater Sump		25
Building Overhang		11	Sewer - Building Sanitary		30
Foundation Drain to Clearwater		12	Septic or Holding, or POWTS Tank		36

Comment:

Created On: 01-24-1996

Updated On: 07-05-2019

Review Status: