

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KO910		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner WISKIRCHIN, STEVEN						Phone #		1. Well Location				Fire # (if avail.)							
Mailing Address 8960 TOWN LINE RD						Town of WAYNE													
City KEWASKUM						State WI		Zip Code 53040											
County Washington		Co. Permit #		Notification #		Completed 12-14-1995		Subdivision Name				Lot # Block #							
Well Constructor (Business Name) HOWARD H GROTH				Lic. # 651		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address W69 N949 WASHINGTON CEDARBURG WI 53012				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 12 12 N 18 E		2. Well Type New Well				of previous unique well # constructed in							
Hicap Permanent Well #		Common Well #		Specific Capacity 0.3		Reason for replaced or reconstructed well ? WATER													
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled													
Heat Exchange ___ # of drillholes				Hicap Property ? No															
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method												8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)					
8		Surface		52		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				S G		SAND @ STONES		Surface 35					
6		52		145						L		LIMESTONE		35 142					
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		12 ft. below ground surface				12 in. above grade					
6		1897 LB ASTMA53 PE IPSCO				Surface		52		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 65 ft. below surface				Disinfected ? Yes					
										Pumping at 15 GP M for 2 Hrs.				Capped ? Yes					
										Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?							
Method HALABURTON SINGLE PLUG												Filled & Sealed Well(s) as needed?							
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement													
NEAT CEMENT GROUT		Surface		52		7 S						13. Constructor / Supervisory Driller				Lic #		Date Signed	
												HG				12-26-1995			
												Drill Rig Operator		Lic or Reg #		Date Signed			
												JG				12-26-1995			

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		160	Clearwater Sump		12
Building Drain - Sanitary		25	Foundation Drain to Clearwater		11
Building Overhang		10	Sewer - Building Sanitary		75
			Septic or Holding, or POWTS Tank		100

Comment:

Created On: 01-24-1996

Updated On: 01-24-1996

Review Status: