Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KO927

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WILKINSON, TIMOTHY L			Phone #: (262)376-1141
Mailing Address: 1489 CEDARTON PARKWAY			
City: GRAFTON	State: WI	Zip Code: 53024	
County: Ozaukee	Co. Permit #:	Notification #:	Completed: 03-22-1996

1. Well Location

Town of CEDARBURG

Fire # (if avail.):

Street Address or Road Name and Number: 1489 CEDARTON PKWY

Subdivision Name	Lot #	Block #
CEDARTON ESTATES	3	

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
GROTH DRILLING CO INC	639	

Address: W69 N949 WASHINGTON CEDARBURG WI 53012

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Latitude / Longitude in Decimal Degree (DD): 43.3299 °N -87.9791 °W

Method Code: GCD013

SE	NW	Section	Township	Range
or Govt Lot #		14	10 N	21 E

2. Well Type New Well

of previous unique well #: constructed in

Reason for replaced or reconstructed well ?: WATER

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.3

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	56
6	56	175

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X	G	SANDY CLAY @ STONES	Surface	48
		C	S	SANDY CLAY	48	54
		L		LIMESTONE	54	175

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	18 97 LB ASTM A 53 PE PUSAN	Surface	56
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

30 ft. below ground surface

10. Pump Test

Pumping level 65 ft. below surface

Pumping at 12 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILLING MUD	Surface	56	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
HG		04-16-1996
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		54
Building Drain - Sanitary		70
Building Overhang		7
Clearwater Sump		51
Foundation Drain to Clearwater		28
Sewer - Building Sanitary		48

Comment:

Created On: 05-24-1996 Updated On: 07-15-2019 Review Status: