Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KO928

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: WENDT, GERALD			Phone #
Mailing Address: 12203 W FREISDAT RD			
City: MEQUON	State: WI	Zip Code: 53097	
County: Ozaukee	Co. Permit #	Notification #	Completed: 03-12-1996

1. Well Location

City of MEQUON

Fire # (if avail.)

Street Address or Road Name and Number: 12203 W FREISTADT RD 120N

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
GROTH DRILLING CO INC	639	

Address: W69 N949 WASHINGTON CEDARBURG WI 53012

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Latitude / Longitude in Decimal Degree (DD): 43.2352 °N -88.0611 °W

Method Code: GCD013

NW or Govt Lot #	NW	Section	Township	Range
		19	9 N	21 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

WATER

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.9

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	125

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		SOIL	Surface	0.03
		Y		GRAVEL SAN	3	22
		Z	L	GRAVEL CLAY LIMESTONE	22	26
		C	S	SANDY CLAY	26	56
		S		SAND	56	80
		Z	S	GRAVEL SANDY CLAY	80	84
		L		LIMESTONE	84	125

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
0.006	1897 LB ASTMA53 PE IPSCO	Surface	84
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

24 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
HG		03-26-1996
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100
Building Overhang		45
Downspout/Yard Hydrant		36
Sewer - Building Sanitary		63
Septic or Holding, or POWTS Tank		81

Comment:

Created On: 05-16-1996 Updated On: 07-15-2019 Review Status: