

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KQ392		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner HUSS, PAUL						Phone # (414)499-4946		1. Well Location				Fire # (if avail.)									
Mailing Address 1351 WESTERN AVE						Town of DOTY						Street Address or Road Name and Number									
City GREEN BAY				State WI		Zip Code 54303		Subdivision Name				Lot #		Block #							
County Oconto		Co. Permit #		Notification #		Completed 03-13-1996															
Well Constructor (Business Name) NOBLE F JONES				Lic. # 640		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address RT 2 10460 HWY A SURING WI 54174-9802				Well Plan Approval #		SE		NE		Section 26		Township 32 N		Range 15 E							
						or Govt Lot #															
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3		2. Well Type New Well													
Reason for replaced or reconstructed well ? OPEN LOT																					
3. Well serves # of Private, potable				Hicap Well ? No		Hicap Property ? No															
Heat Exchange ____ # of drillholes				Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		20						S		SAND				Surface		35			
6		20		66		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)				X		SAND CLAY MIX		35		60					
										N S		SAND FINE BROWN		60		66					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				12 in. above grade							
6		ASTM A53 18 97 LB SAWHILL STEEL WELDED				Surface		62		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 55 ft. below surface				Disinfected ? Yes							
5		STAINLESS STEEL TELESOPING				62		66		Pumping at 20 GP M for 0.5 Hrs.				Capped ? Yes							
										Pumping Method ?											
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method MUD CIRC														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
DRILLING MUD				Surface		20				13. Constructor / Supervisory Driller				Lic #		Date Signed					
										NJ						04-07-1996					
										Drill Rig Operator				Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Shoreline/Pool		40

Comment:

Created On: 06-12-1996

Updated On: 06-12-1996

Review Status: