Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KQ394

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FOREST CO POTAWATOMI HOUSING	Phone #: (715)478-2903
Mailing Address: PO BOX 340	
City: CRANDON	State: WI — Zip Code: 54520
County: Forest	Co. Permit #: — Notification #: — Completed: 04-01-1996
Well Constructor (Business Name): NOBLE F JONES	Lic. #: 640 — Facility ID # (Public Wells):
Address: RT 2 10460 HWY A, SURING WI 54174-9802	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 1.3

1. Well Location

Town of WAKENO

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SE	NW	Section	Township	Range
or Govt Lot #		28	34 N	15 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?

COMMUNITY WELL NO 1

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
16	Surface	15
12	15	80
8	80	207

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Yes — Temp. Outer Casing 16in. dia
Yes — Removed? ____depth ft. (If NO explain on back side)

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
12	ASTM A 53 49 56 LBS SAWHILL STEEL WELDED	Surface	54
8	ASTM A 53 28 55 LBS SAWHILL STEEL WELDED	54	191
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL TELESCOPING 0 012 SLOT	191	207

7. Grout or Other Sealing Material

Method CONDUCTOR PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	80	65

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z	G	CLAY GRAVEL MIX WITH STONES	Surface	80
	A	S		STICKY COARSE SAND GREY	80	95
	A	S		COARSE SAND	95	109
		X		CLAY SAND MIX	109	114
		Y	C	SAND GRAVEL CLAY MIX	114	160
		X		CLAY SAND MIX	160	188
		G		GRAVEL	188	191
		S		SAND	191	207

9. Static Water Level

80 ft. below ground surface

10. Pump Test

Pumping level 163 ft. below surface

Pumping at 105 GP M for 8 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
NJ		09-13-1996
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-18-1997 Updated On: 03-18-1997 Review Status: