

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KQ394		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner FOREST CO POTAWATOMI HOUSING						Phone # (715)478-2903		1. Well Location				Fire # (if avail.)									
Mailing Address PO BOX 340						Town of WAKENO															
City CRANDON						State WI		Zip Code 54520													
County Forest		Co. Permit #		Notification #		Completed 04-01-1996		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) NOBLE F JONES				Lic. # 640		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code									
Address RT 2 10460 HWY A SURING WI 54174-9802				Well Plan Approval #		SE NW		Section 28		Township 34 N		Range 15 E									
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 1.3		2. Well Type New Well											
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ? COMMUNITY WELL NO 1															
3. Well serves 1 # of Private, potable				Heat Exchange ___ # of drillholes		Construction Type Drilled															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method																					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		8. Geology									
16		Surface		15		Yes Rotary - Mud Circulation						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)			
12		15		80		Rotary - Air						Z G		CLAY GRAVEL MIX WITH STONES		Surface		80			
8		80		207		Rotary - Air & Foam						A S		STICKY COARSE SAND GREY		80		95			
						Drill-Through Casing Hammer						A S		COARSE SAND		95		109			
						Reverse Rotary						X		CLAY SAND MIX		109		114			
						Cable-tool Bit ___ in. dia...						Y C		SAND GRAVEL CLAY MIX		114		160			
						Dual Rotary						X		CLAY SAND MIX		160		188			
						Yes Temp. Outer Casing 16in. dia						G		GRAVEL		188		191			
						Yes Removed? ___ depth ft. (If NO explain on back side)						S		SAND		191		207			
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		80 ft. below ground surface				24 in. above grade							
12		ASTM A 53 49 56 LBS SAWHILL STEEL WELDED				Surface		54		10. Pump Test				Developed ? Yes							
8		ASTM A 53 28 55 LBS SAWHILL STEEL WELDED				54		191		Pumping level 163 ft. below surface				Disinfected ? Yes							
										Pumping at 105 GP M for 8 Hrs.				Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping Method ?											
6		STAINLESS STEEL TELESOPING 0 012 SLOT				191		207													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method CONDUCTOR PIPE PUMPED														Filled & Sealed Well(s) as needed?							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement						13. Constructor / Supervisory Driller				Lic #		Date Signed	
NEAT CEMENT				Surface		80		65						NJ				09-13-1996			
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 03-18-1997

Updated On: 03-18-1997

Review Status: