Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KQ395

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FOREST CTY POTAWATOMI HOUSING	Phone #: (715)478-2903
Mailing Address: PO BOX 340	
City: CRANDON	State: WI Zip Code: 54520
County: Forest	Co. Permit #:
Notification #	Completed: 08-30-1996
Well Constructor (Business Name): NOBLE F JONES	Lic. #: 640
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: RT 2 10460 HWY A SURING WI 54174-9802	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #:
Specific Capacity: 0.7	

1. Well Location

Town of WAKENO

Fire # (if avail.)

Street Address or Road Name and Number

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

SE NW or Govt Lot #	Section: 28	Township: 34 N	Range: 15 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?

COMMUNITY WELL NO 2

Construction Type: Drilled

3. Well serves # of COMMUNITY WELL

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? Yes

Hicap Property ? Yes

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
16	Surface	13
12	13	186
8	186	211

Upper Enlarged Drillhole / Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Yes Temp. Outer Casing 16in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Z	G	CLAY GRAVEL WITH STONES	Surface	30
		X		CLAY SAND MIX	30	80
T		S		SAND BROWN	80	115
		Y		CLAY SAND MIX	115	130
		Y	C	SAND GRAVEL CLAY MIX	130	165
		X		CLAY SAND MIX	165	186
	H	S		CEMENTED SAND	186	211

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
8	ASTM A 53 28 55 LBS SAWHILL STEEL WELDED	Surface	186
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	STAINLESS STEEL TELESCOPING 0 020 SLOT	191	211

9. Static Water Level

76.5 ft. below ground surface

10. Pump Test

Pumping level 161 ft. below surface

Pumping at 55 GP M for 8 Hrs.

Pumping Method ?

11. Well Is

24 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method CONDUCTOR PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	84	70 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
NJ		09-13-1996
Drill Rig Operator	Lic or Reg #	Date Signed
LJ		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-18-1997 Updated On: 03-18-1997 Review Status: