

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KQ395		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A									
Property Owner FOREST CTY POTAWATOMI HOUSING						Phone # (715)478-2903		1. Well Location				Fire # (if avail.)							
Mailing Address PO BOX 340						Town of WAKENO						Street Address or Road Name and Number							
City CRANDON				State WI		Zip Code 54520													
County Forest		Co. Permit #		Notification #		Completed 08-30-1996		Subdivision Name			Lot #		Block #						
Well Constructor (Business Name) NOBLE F JONES				Lic. # 640		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code							
Address RT 2 10460 HWY A SURING WI 54174-9802				Well Plan Approval #		SE NW Section Township Range or Govt Lot # 28 34 N 15 E		2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? COMMUNITY WELL NO 2											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.7						Approval Date (mm-dd-yyyy)							
3. Well serves # of COMMUNITY WELL Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? Yes Hicap Property ? Yes Hicap Potable ?		Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																			
5. Drillhole Dimensions and Construction Method																			
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock																
16 Surface 13			<u>Yes</u> Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary <u>Yes</u> Temp. Outer Casing 16in. dia Removed? ___ depth ft. (If NO explain on back side)																
12 13 186																			
8 186 211																			
8. Geology																			
Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...						From (ft.) To (ft.)										
T Z G			CLAY GRAVEL WITH STONES						Surface 30										
X			CLAY SAND MIX						30 80										
S			SAND BROWN						80 115										
Y			CLAY SAND MIX						115 130										
Y C			SAND GRAVEL CLAY MIX						130 165										
X			CLAY SAND MIX						165 186										
H S			CEMENTED SAND						186 211										
6. Casing, Liner, Screen																			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		9. Static Water Level 76.5 ft. below ground surface				11. Well Is 24 in. above grade							
8		ASTM A 53 28 55 LBS SAWHILL STEEL WELDED				Surface 186													
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		10. Pump Test Pumping level 161 ft. below surface Pumping at 55 GP M for 8 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
6		STAINLESS STEEL TELESCOPING 0 020 SLOT				191 211													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?							
Method CONDUCTOR PIPE PUMPED																			
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement		NEAT CEMENT Surface 84 70 S													
13. Constructor / Supervisory Driller												Lic #		Date Signed					
NJ												09-13-1996		Drill Rig Operator		Lic or Reg #		Date Signed	
LJ												09-13-1996							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 03-18-1997

Updated On: 03-18-1997

Review Status: