Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KR550

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FOUNTAINE, TAD	Phone #: (262)279-5696
Mailing Address: N915 ROSE DR	
City: GENOA CITY	State: WI Zip Code: 53128
County: Walworth	Co. Permit #:
Notification #	Completed: 04-20-2004
Well Constructor (Business Name): MICHAEL W SHEETS	Lic. #: 5497
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: SHEETS WELL & PUMP SERVICE RICHMOND IL 60071-9716	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity	

1. Well Location

Village of GENOA CITY

Fire # (if avail.): W182

Street Address or Road Name and Number: TULIP

Subdivision Name	Lot #	Block #
ROSE NIP GRDNS		

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

NE SE or Govt Lot #	Section	Township	Range
	24	1 N	18 E

2. Well Type New Well — ZS799 replaces this well of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ? No

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	8
5	8	71

Upper Enlarged Drillhole		Lower Open Bedrock
No	Rotary - Mud Circulation	No
No	Rotary - Air	No
No	Rotary - Air & Foam	No
No	Drill-Through Casing Hammer	
No	Reverse Rotary	
Yes	Cable-tool Bit 5in. dia...	No
No	Dual Rotary	No
Yes	Temp. Outer Casing 10in. dia	
Yes	Removed? ____depth ft. (If NO explain on back side)	

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	-	I	-	TOPSOIL	Surface	3
T	-	S	-	BRN SAND	3	24
G	-	C	-	GRAY CLAY	24	42
-	-	G	U	DIRTY GRAVEL	42	45
-	-	P	-	HARDPAN	45	69
G	-	Y	-	GRAY SAND/GRAVEL	69	74

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	A53 T&C 15# PER FT	Surface	71
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	SS WIRE WRAP #20	71	74

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE/CLAY CUTTINGS	Surface		

9. Static Water Level
25 ft. below ground surface

10. Pump Test
Pumping level 25 ft. below surface
Pumping at 10 GP M for 20 Hrs.
Pumping Method ?

11. Well Is
16 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ? No

Filled & Sealed Well(s) as needed? No
NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
MD		05-10-2004
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Foundation Drain to Clearwater		35
Building Overhang		14	Septic or Holding, or POWTS Tank		60

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	05/06/2019	BENTONITE CHIPS 0-74' 14 SACKS USED	PRODUCING SEDIMENT & < 1 GPM WATER PRODUCTION

Created On: 06-03-2004 Updated On: 05-13-2019 Review Status: