

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KR550		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner FOUNTAINE, TAD						Phone # (262)279-5696		1. Well Location				Fire # (if avail.)					
Mailing Address N915 ROSE DR						Village of GENOA CITY						W182					
City GENOA CITY						State WI		Zip Code 53128				Street Address or Road Name and Number					
County Walworth						Co. Permit #		Notification #		Completed 04-20-2004		Subdivision Name ROSE NIP GRDNS		Lot #		Block #	
Well Constructor (Business Name) MICHAEL W SHEETS						Lic. # 5497		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address SHEETS WELL & PUMP SERVICE RICHMOND IL 60071-9716						Well Plan Approval #		Approval Date (mm-dd-yyyy)		°N		°W		Range			
										NE		SE				Section 24	
Hicap Permanent Well #						Common Well #		Specific Capacity		2. Well Type New Well ZS799 replaces this well of previous unique well # constructed in							
3. Well serves 1 # of Private, potable						Hicap Well ? No		Hicap Property ? No		Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes						Hicap Potable ? No		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
10		Surface		8		No Rotary - Mud Circulation				No							
5		8		71		No Rotary - Air				No							
						No Rotary - Air & Foam				No							
						No Drill-Through Casing Hammer											
						No Reverse Rotary											
						Yes Cable-tool Bit 5in. dia...				No							
						No Dual Rotary				No							
						Yes Temp. Outer Casing 10in. dia											
						Yes Removed? ___ depth ft. (If NO explain on back side)											
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
- - I -				TOPSOIL				Surface		3							
T - S -				BRN SAND				3		24							
G - C -				GRAY CLAY				24		42							
- - G U				DIRTY GRAVEL				42		45							
- - P -				HARDPAN				45		69							
G - Y -				GRAY SAND/GRAVEL				69		74							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
5		A53 T&C 15# PER FT				Surface		71									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
4		SS WIRE WRAP #20				71		74									
7. Grout or Other Sealing Material																	
Method																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
BENTONITE/CLAY CUTTINGS				Surface													
9. Static Water Level																	
25 ft. below ground surface																	
10. Pump Test																	
Pumping level 25 ft. below surface																	
Pumping at 10 GP M for 20 Hrs.																	
Pumping Method ?																	
11. Well Is																	
16 in. above grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ? No																	
Filled & Sealed Well(s) as needed? No																	
NA																	
13. Constructor / Supervisory Driller				Lic #		Date Signed											
MD						05-10-2004											
Drill Rig Operator				Lic or Reg #		Date Signed											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		90	Foundation Drain to Clearwater		35
Building Overhang		14	Septic or Holding, or POWTS Tank		60

Comment:

Abandonment Type	Abandonment Date	Procedure	Reason
	05/06/2019	BENTONITE CHIPS 0-74' 14 SACKS USED	PRODUCING SEDIMENT & < 1 GPM WATER PRODUCTION

Created On: 06-03-2004

Updated On: 05-13-2019

Review Status: