

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KR667		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner BOBRICK, CHARLA						Phone # (414)843-3840		1. Well Location				Fire # (if avail.)											
Mailing Address 10210 256TH AVE						Town of SALEM						Street Address or Road Name and Number 10210 256TH AVE											
City SALEM				State WI		Zip Code 53168																	
County Kenosha		Co. Permit #		Notification #		Completed 08-29-1996		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) HUEMANN JOS H @ SONS INC				Lic. # 585		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.528 °N -88.119 °W			Method Code GCD013										
Address 5205 S RT 31 RINGWOOD IL 60072				Well Plan Approval #				NE SW		Section 22		Township 1 N		Range 20 E									
				Approval Date (mm-dd-yyyy)				or Govt Lot #		22		1 N		20 E									
Hicap Permanent Well #			Common Well #			Specific Capacity 2.1				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW CONST													
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?																	
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
9		Surface		56		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				C		CLAY		Surface		22							
5		200 L BPSI PVC 1120 SDR 21 ASTM F480 91 NSF WC CERTAINTED SOLVENT WELD		Surface		52		G		GRAVEL		22		28									
5.625		15 SLOT SS SCREEN		52		56		C		CLAY		28		52									
5.625		15 SLOT SS SCREEN		52		56		G		GRAVEL		52		56									
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				12 in. above grade									
5		200 L BPSI PVC 1120 SDR 21 ASTM F480 91 NSF WC CERTAINTED SOLVENT WELD				Surface		52		Pumping level 27 ft. below surface				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping at 25 GP M for 6 Hrs.				Disinfected ? Yes									
5.625		15 SLOT SS SCREEN				52		56		Pumping Method ?				Capped ? Yes									
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?									
Method														Filled & Sealed Well(s) as needed? No NA									
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement															
BENTONITE GROUT				Surface		52																	
13. Constructor / Supervisory Driller										Lic #		Date Signed											
JH												10-15-1996											
Drill Rig Operator										Lic or Reg #		Date Signed											
JS												10-15-1996											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		18
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-08-1997

Updated On: 08-23-2019

Review Status: