Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KR667

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOBRICK, CHARLA	Phone #: (414)843-3840
Mailing Address: 10210 256TH AVE	
City: SALEM	State: WI — Zip Code: 53168
County: Kenosha	Co. Permit #:
Notification #	Completed: 08-29-1996
Well Constructor (Business Name): HUEMANN JOS H @ SONS INC	Lic. #: 585
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: 5205 S RT 31 RINGWOOD IL 60072	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 2.1	

1. Well Location

Town of SALEM

Fire # (if avail.)

Street Address or Road Name and Number: 10210 256TH AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
42.528 °N -88.119 °W	GCD013

NE SW or Govt Lot #	Section	Township	Range
	22	1 N	20 E

2. Well Type New Well

of previous unique well # constructed in

Reason for replaced or reconstructed well ?: NEW CONST

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
9	Surface	56

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	22
G	GRAVEL	22	28
C	CLAY	28	52
G	GRAVEL	52	56

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
5	200 L BPSI PVC 1120 SDR 21 ASTM F480 91 NSFWC CERTAINTEED SOLVENT WELD	Surface	52
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5.625	15 SLOT SS SCREEN	52	56

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 27 ft. below surface

Pumping at 25 GP M for 6 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GROUT	Surface	52	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
JH		10-15-1996
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
JS		10-15-1996

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		65	Building Overhang		18
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 01-08-1997 Updated On: 08-23-2019 Review Status: