

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KR760		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner GANTER, VICTOR						Phone # (414)650-0922		1. Well Location				Fire # (if avail.)	
Mailing Address W224 S5050 GUTHRIE						Town of WAUKESHA							
City WAUKESHA						State WI		Zip Code 53186					
County Waukesha		Co. Permit #		Notification #		Completed 12-21-1996		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) STEVE HARTMAN				Lic. # 324		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.9524 °N -88.1958 °W			
Address W224 S8490 INDUSTRIA BIG BEND WI 53103				Well Plan Approval #		Method Code GCD013							
						SW NE Section Township Range or Govt Lot # 25 6 N 19 E							
Approval Date (mm-dd-yyyy)				Approval Date (mm-dd-yyyy)		2. Well Type New Well							
Hicap Permanent Well #				Common Well #		Specific Capacity 1.3				of previous unique well # constructed in			
3. Well serves 1 # of Private, potable				Hicap Well ? No		Reason for replaced or reconstructed well ?							
Heat Exchange ___ # of drillholes				Hicap Property ? No		WATER							
				Hicap Potable ?		Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
6		Surface		105		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)							
8. Geology													
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
Y		SAND @ GRAVEL				Surface		53					
C		CLAY				53		89					
G		GRAVEL				89		96					
B L		BROKEN LIMESTONE				96		100					
L		LIMESTONE				100		105					
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		NEW BLACK PE ASTM A53B 19# SAWHILL STEEL				Surface		100					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
7. Grout or Other Sealing Material													
Method													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
NONE REQUIRED				Surface		0							
9. Static Water Level													
20 ft. below ground surface													
10. Pump Test													
Pumping level 40 ft. below surface													
Pumping at 25 GP M for 2 Hrs.													
Pumping Method ?													
11. Well Is													
12 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? No													
NONE													
13. Constructor / Supervisory Driller													
Lic #				Date Signed									
SH				12-21-1996									
Drill Rig Operator				Lic or Reg #				Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		200	Downspout/Yard Hydrant		20
Building Overhang		15	Wastewater Sump		75
Clearwater Sump		50	Septic or Holding, or POWTS Tank		100

Comment:

Created On: 10-03-1997

Updated On: 07-11-2019

Review Status: