Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KS997

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: ZAMZOW, TERRY			Phone #: (920)324-3293
Mailing Address: W9901 NEITMAN RD			
City: WAUPUN	State: WI	Zip Code: 53963	
County: Fond du Lac	Co. Permit #:	Notification #:	Completed: 08-07-1997

Well Constructor (Business Name): ZOELLNER CENTRAL WELL DRILLING	Lic. #: 4231	Facility ID # (Public Wells):	
Address: PO BOX 405 BRANDON WI 53919-0405		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 1.9	

1. Well Location

Town of WAUPUN

Fire # (if avail.):

Street Address or Road Name and Number:

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): 43.68106 °N -88.65449 °W				Method Code: GPS008
SW SE or Govt Lot #:	Section: 13	Township: 14 N	Range: 15 E	

2. Well Type New Well

of previous unique well #: constructed in:

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	62
6	62	218

Upper Enlarged Drillhole

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

Lower Open Bedrock

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	5
		G	G	GRAVEL @ BOULDERS	5	32
		L		LIMEROCK	32	195
		N		SANDROCK	195	218

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 1897 #PER FT 1780 PSI API 5L GRBPE USA IPSCO	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 36 ft. below surface

Pumping at 15 GP M for 3 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD @ CUTTINGS	Surface	6	
CEMENT	6	62	11 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJS		08-01-1997
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100

Type	Qualifier	Distance
Building Overhang		18
Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 10-20-1997 Updated On: 09-08-2022 Review Status: