Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KS999

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: FOLBRECHT, HAROLD	Phone #: (920)885-2316
Mailing Address: N7332 CRYSTAL RIDGE DR	
City: BEAVER DAM	State: WI — Zip Code: 53916
County: Dodge	Co. Permit #:
Notification #	Completed: 08-05-1997
Well Constructor (Business Name): ZOELLNER CENTRAL WELL DRILLING	Lic. #: 4231
Facility ID # (Public Wells)	
Well Plan Approval #	
Address: PO BOX 405 BRANDON WI 53919-0405	
Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #
Specific Capacity: 0.6	

1. Well Location

Town of BEAVER DAM

Fire # (if avail.)

Street Address or Road Name and Number: N7332 CRYSTAL RIDGE DR

Subdivision Name	Lot #	Block #
CRYSTAL RDG	3	

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.4603 °N -88.8002 °W	GCD013

SW SW or Govt Lot #	Section: 35	Township: 12 N	Range: 14 E

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	62
6	62	151

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
C	CLAY	Surface	2
Z	CLAY @ GRAVEL	2	45
L	LIMEROCK	45	116
N	SANDROCK	116	151

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLACK STEEL 1897 #PER FT 1780 PSI API5L GRBPE USA IPSCO	Surface	62
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

20 ft. below ground surface

10. Pump Test

Pumping level 55 ft. below surface

Pumping at 20 GP M for 1 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD @ CUTTINGS	Surface	6	
CEMENT	6	62	10 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NA

13. Constructor / Supervisory Driller	Lic #	Date Signed
TRO		08-05-1997
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		17

Comment:

Created On: 10-20-1997 Updated On: 10-01-2019 Review Status: