

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KS999		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A					
Property Owner FOLBRECHT, HAROLD						Phone # (920)885-2316		1. Well Location				Fire # (if avail.)			
Mailing Address N7332 CRYSTAL RIDGE DR						Town of BEAVER DAM						Street Address or Road Name and Number N7332 CRYSTAL RIDGE DR			
City BEAVER DAM				State WI		Zip Code 53916									
County Dodge		Co. Permit #		Notification #		Completed 08-05-1997		Subdivision Name CRYSTAL RDG				Lot # 3		Block #	
Well Constructor (Business Name) ZOELLNER CENTRAL WELL DRILLING				Lic. # 4231		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 43.4603 °N -88.8002 °W				Method Code GCD013	
Address PO BOX 405 BRANDON WI 53919-0405				Well Plan Approval #				SW SW		Section 35		Township 12 N		Range 14 E	
				Approval Date (mm-dd-yyyy)				or Govt Lot #		35		12 N		14 E	
Hicap Permanent Well #				Common Well #		Specific Capacity 0.6				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME					
3. Well serves 1 # of Private, potable Heat Exchange ____ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled									
4. Potential Contamination Sources - ON REVERSE SIDE															
5. Drillhole Dimensions and Construction Method															
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock					
8.75		Surface		62		Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ____ in. dia... Dual Rotary Temp. Outer Casing ____ in. dia Removed? ____ depth ft. (If NO explain on back side)									
6		62		151											
8. Geology															
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)					
C				CLAY				Surface		2					
Z				CLAY @ GRAVEL				2		45					
L				LIMEROCK				45		116					
N				SANDROCK				116		151					
6. Casing, Liner, Screen															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)							
6		NEW BLACK STEEL 1897 #PER FT 1780 PSI API5L GRBPE USA IPSCO				Surface		62							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)							
7. Grout or Other Sealing Material															
Method TREMIE PIPE PUMPED															
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement							
MUD @ CUTTINGS				Surface		6									
CEMENT				6		62		10 S							
9. Static Water Level															
20 ft. below ground surface															
10. Pump Test															
Pumping level 55 ft. below surface Pumping at 20 GP M for 1 Hrs. Pumping Method ?															
11. Well Is															
12 in. above grade Developed ? Yes Disinfected ? Yes Capped ? Yes															
12. Notified Owner of need to fill & seal ?															
Filled & Sealed Well(s) as needed? NA															
13. Constructor / Supervisory Driller								Lic #		Date Signed					
TRO										08-05-1997					
Drill Rig Operator								Lic or Reg #		Date Signed					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance
Building Overhang		17

Comment:

Created On: 10-20-1997

Updated On: 10-01-2019

Review Status: