Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KX811

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PAULSON, CRAIG			Phone #: (715)251-1156
Mailing Address: W7150 HWY 8			
City: NIAGARA	State: WI	Zip Code: 54151	
County: Marinette	Co. Permit #:	Notification #:	Completed: 07-01-1996

1. Well Location

Town of NIAGARA

Fire # (if avail.): W7150

Street Address or Road Name and Number: W7150 HWY 8

Subdivision Name	Lot #	Block #

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
MAURICE JOHNSON	664	

Latitude / Longitude in Decimal Degree (DD): 45.7482 °N -87.9464 °W

Method Code: GCD013

Well Plan Approval #:

SE NW or Govt Lot #	Section	Township	Range
	24	38 N	20 E

Address: N19382 CO O
PEMBINE WI 54156-9801

Approval Date (mm-dd-yyyy):

2. Well Type New Well

of previous unique well #: constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.1

Reason for replaced or reconstructed well ?: UPGRADE HOME

3. Well serves 1 # of HOME

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	300

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
	Q	Y		SAND GRAVEL CAVING	Surface	26
		Z		CLAY GRAVEL	26	58
G		Q		GREY GRANITE	58	300

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B SAWHILL 280 W 18 97 LB FT WELDED	Surface	58
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
	NOT INSTALLED		

9. Static Water Level

14 ft. below ground surface

10. Pump Test

Pumping level 40 ft. below surface

Pumping at 2 GP M for 48 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method: MOUNDED BENTONITE

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRAN BENTONITE	Surface	58	3 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? No

CUSTOMER IS USING NON PORTABLE

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		07-09-1996
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
DJM		07-05-1996

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75
Building Drain - Sanitary		60
Building Overhang		27
Sewer - Building Sanitary		61
Septic or Holding, or POWTS Tank		63

Comment:

Created On: 07-26-1996 Updated On: 10-22-2019 Review Status: