Well Construction Report
WISCONSIN UNIQUE WELL NUMBER KX821

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HAZELWOOD, JIM	Phone #: (715)696-3450
Mailing Address: RT 2 BOX 964A	
City: FLORENCE	State: WI — Zip Code: 54121
County: Florence	Co. Permit #: — Notification #: — Completed: 07-25-1996
Well Constructor (Business Name): MAURICE JOHNSON	Lic. #: 664 — Facility ID # (Public Wells):
Address: N19382 CO O PEMBINE WI 54156-9801	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.5

1. Well Location

Fire # (if avail.):

Town of FLORENCE

Street Address or Road Name and Number: OLD 69 ROAD

Subdivision Name: — Lot #: — Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:

SW SW or Govt Lot # — Section: 4 — Township: 39 N — Range: 19 E

2. Well Type New Well

of previous unique well #: — constructed in:

Reason for replaced or reconstructed well ?: NEW HOME

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	115

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	43
		C	S	SANDY CLAY	43	94
I		Q		ORE ROCK SOFT RED	94	115

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTMA53B SAWHILL 280 1897 LB FT WELDED	Surface	98
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method

9. Static Water Level

40 ft. below ground surface

10. Pump Test

Pumping level 50 ft. below surface

Pumping at 5 GP M for 15 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		10-28-1996
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 01-09-1997 Updated On: 01-09-1997 Review Status: