

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KX821		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner HAZELWOOD, JIM						Phone # (715)696-3450		1. Well Location				Fire # (if avail.)											
Mailing Address RT 2 BOX 964A						Town of FLORENCE						Street Address or Road Name and Number OLD 69 ROAD											
City FLORENCE				State WI		Zip Code 54121																	
County Florence		Co. Permit #		Notification #		Completed 07-25-1996		Subdivision Name			Lot #		Block #										
Well Constructor (Business Name) MAURICE JOHNSON				Lic. # 664		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code											
Address N19382 CO O PEMBINE WI 54156-9801				Well Plan Approval #		SW		SW		Section 4		Township 39 N		Range 19 E									
				Approval Date (mm-dd-yyyy)		or Govt Lot #		4		39 N		19 E											
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5		2. Well Type New Well															
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		of previous unique well # _____ constructed in _____ Reason for replaced or reconstructed well ? NEW HOME															
						Hicap Property ? No																	
4. Potential Contamination Sources - ON REVERSE SIDE						Hicap Potable ?		Construction Type Drilled															
5. Drillhole Dimensions and Construction Method														8. Geology									
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)	
6		Surface		115		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				S SAND C S SANDY CLAY Q ORE ROCK SOFT RED				Surface		43							
														43		94							
														94		115							
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is					
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				18 in. above grade									
6		ASTMA53B SAWHILL 280 1897 LB FT WELDED				Surface		98		10. Pump Test Pumping level 50 ft. below surface Pumping at 5 GP M for 15 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)															
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed?									
										13. Constructor / Supervisory Driller				Lic #		Date Signed							
										MJ						10-28-1996							
										Drill Rig Operator				Lic or Reg #		Date Signed							

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 01-09-1997

Updated On: 01-09-1997

Review Status: