

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KY655		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner WIECZOREK, GENE						Phone # (414)639-3944		1. Well Location				Fire # (if avail.)		
Mailing Address 5317 WIND POINT RD						Town of CALEDONIA								
City RACINE						State WI		Zip Code 53402-2322				Street Address or Road Name and Number 5201 ALEXANDER DR		
County Racine		Co. Permit #		Notification #		Completed 06-27-1997		Subdivision Name RIVER MDWS				Lot # Block #		
Well Constructor (Business Name) HOOVER WATER WELL SERVICE INC				Lic. # 311		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code		
Address 21445 DURAND AVE UNION GROVE WI 53182-9711				Well Plan Approval #		SW SE Section Township Range or Govt Lot # 23 4 N 22 E		2. Well Type New Well				of previous unique well # constructed in		
Hicap Permanent Well #		Common Well #		Specific Capacity 1		Reason for replaced or reconstructed well ? DOMESTIC WATER SUPPLY								
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled								
Heat Exchange ___ # of drillholes				Hicap Property ? No										
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock											
9 Surface 9			Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)											
6 9 130														
8. Geology														
Dia. (in.)			Material, Weight, Specification Manufacturer & Method of Assembly			From (ft.) To (ft.)		Geology Codes			Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)	
6 SAWHILL STEEL PLAIN END WELDED ASTM A53B 1897 PPF			Surface 42					C CLAY			Surface 15			
Screen type, material & slot size			From (ft.) To (ft.)					P HARDPAN			15 42			
								L LIMESTONE			42 130			
6. Casing, Liner, Screen														
Dia. (in.) Material, Weight, Specification Manufacturer & Method of Assembly						From (ft.) To (ft.)		9. Static Water Level				11. Well Is		
6 SAWHILL STEEL PLAIN END WELDED ASTM A53B 1897 PPF						Surface 42		9 ft. below ground surface				14 in. above grade		
Dia. (in.) Screen type, material & slot size						From (ft.) To (ft.)		10. Pump Test				Developed ? Yes		
								Pumping level 30 ft. below surface				Disinfected ? Yes		
								Pumping at 20 GP M for 6 Hrs.				Capped ? Yes		
								Pumping Method ?						
7. Grout or Other Sealing Material														
Method STARTER HOLE														
Kind of Sealing Material			From (ft.) To (ft.)		# Sacks Cement		12. Notified Owner of need to fill & seal ?							
GRANULAR BENTON			Surface 0				Filled & Sealed Well(s) as needed? UNKNOWN							
13. Constructor / Supervisory Driller														
Lic #						Date Signed								
WM						08-04-1997								
Drill Rig Operator						Lic or Reg #								
						Date Signed								

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		50	Collector Sewer - San or Storm		70
Building Overhang		40	Downspout/Yard Hydrant		45
Clearwater Sump		90	Foundation Drain to Clearwater		45
			Sewer - Building Sanitary		65

Comment:

Created On: 09-23-1997

Updated On: 09-23-1997

Review Status: