

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				KZ096		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner B P T Phone # (715)634-1025						1. Well Location Fire # (if avail.)																			
Mailing Address PO 607						Town of HAYWARD																			
City HAYWARD State WI Zip Code 54843						Street Address or Road Name and Number																			
County Sawyer		Co. Permit #		Notification #		Completed 04-29-1998		Subdivision Name		Lot # Block #															
Well Constructor (Business Name) FROEMEL WELL @ PUMP REPAIR INC				Lic. # 6080		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W		Method Code															
Address RT 5 BOX 5000 F HAYWARD WI 54843				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 23 41 N 9 W		2. Well Type New Well																	
Hicap Permanent Well #				Common Well #		Specific Capacity		Reason for replaced or reconstructed well ?																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Driven Point																	
4. Potential Contamination Sources - ON REVERSE SIDE																									
5. Drillhole Dimensions and Construction Method						8. Geology																			
<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 50%; padding: 5px;"> Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia </td> <td style="width: 50%; padding: 5px;"> Lower Open Bedrock </td> </tr> </table>						Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia	Lower Open Bedrock	<table border="1" style="width:100%; border-collapse: collapse;"> <tr> <td style="width: 10%;">Geology Codes</td> <td style="width: 50%;">Type, Caving/Noncaving, Color, Hardness, etc...</td> <td style="width: 10%;">From (ft.)</td> <td style="width: 10%;">To (ft.)</td> </tr> <tr> <td style="text-align: center;">S</td> <td>SAND</td> <td style="text-align: center;">Surface</td> <td style="text-align: center;">15</td> </tr> <tr> <td style="text-align: center;">A G S</td> <td>SAND @ COARSE GRAVEL WATER</td> <td style="text-align: center;">15</td> <td style="text-align: center;">31</td> </tr> </table>						Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)	S	SAND	Surface	15	A G S	SAND @ COARSE GRAVEL WATER	15	31
Upper Enlarged Drillhole Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia	Lower Open Bedrock																								
Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)																						
S	SAND	Surface	15																						
A G S	SAND @ COARSE GRAVEL WATER	15	31																						
6. Casing, Liner, Screen						9. Static Water Level				11. Well Is															
Removed? ___ depth ft. (If NO explain on back side)						8 ft. below ground surface				12 in. above grade															
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly		From (ft.) To (ft.)		10. Pump Test				Developed ? Yes															
2 GALV STEEL R@D T@C		Surface 28		Pumping level 8 ft. below surface				Disinfected ? Yes		Capped ? Yes															
Dia. (in.)		Screen type, material & slot size		From (ft.) To (ft.)		Pumping at 8 GP M for 1 Hrs.				Pumping Method ?															
2 60# FIBERGLASS CAMBLE		28 31		Filled & Sealed Well(s) as needed?				13. Constructor / Supervisory Driller		Lic # Date Signed															
7. Grout or Other Sealing Material Method						12. Notified Owner of need to fill & seal ?				DF 05-01-1998															
Method						Drilled & Sealed Well(s) as needed?				Drill Rig Operator															
Method						Drilled & Sealed Well(s) as needed?				Lic or Reg # Date Signed															

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		60	Building Overhang		3
			Septic or Holding, or POWTS Tank		40

Comment:

Created On: 10-19-1998

Updated On: 10-19-1998

Review Status: