Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LB188

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: SEDLACK, ELLEN			Phone #: (715)358-2892
Mailing Address: PO BOX 258			
City: WOODRUFF	State: WI	Zip Code: 54568	
County: Oneida	Co. Permit #:	Notification #:	Completed: 10-26-1998

Well Constructor (Business Name): RICHARDSON WELL DRILLING INC	Lic. #: 315	Facility ID # (Public Wells):	
Address: HWY 70 W 10681 MINOCQUA WI 54548		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of WOODRUFF

Fire # (if avail.): 318

Street Address or Road Name and Number: BIRCH ST @ 3RD AVE

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code:

SE SE or Govt Lot #	Section: 2	Township: 39 N	Range: 6 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	34

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	34

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ASTM A53 WELD 18 97 LBS SAWHILL USA	Surface	27
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	JOHNSON 10 SLOT	27	34

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NA	Surface	0	

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 15 ft. below surface
Pumping at 9 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MHH		10-26-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		15
			Septic or Holding, or POWTS Tank		30

Comment:

Created On: 01-07-1999 Updated On: 01-07-1999 Review Status: