Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LB192

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PROCHAZKA, GERHARD			Phone #: (715)356-4226
Mailing Address: 7719 HWY 51 S			
City: MINOCQUA	State: WI	Zip Code: 54548	
County: Oneida	Co. Permit #:	Notification #:	Completed: 10-30-1998

Well Constructor (Business Name): RICHARDSON WELL DRILLING INC	Lic. #: 315	Facility ID # (Public Wells):	
Address: HWY 70 W 10681 MINOCQUA WI 54548		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 3.8	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.): 7719

Town of MINOCQUA

Street Address or Road Name and Number: HWY 51 S

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
45.8369 °N -89.7113 °W	GCD013

NW SW or Govt Lot #	Section	Township	Range
	26	39 N	6 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	55

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
S	SAND	Surface	40
Y	SAND @ GRAVEL	40	55

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	NEW BLK ASTM A53 WELD 18 97 LBS SAWHILL USA	Surface	52
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
5	JOHNSON 10 SLOT	52	55

7. Grout or Other Sealing Material

Method

9. Static Water Level

26 ft. below ground surface

10. Pump Test

Pumping level 30 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MHH		10-30-1998
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		10
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-07-1999 Updated On: 06-30-2020 Review Status: