

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LB192		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner PROCHAZKA, GERHARD						Phone # (715)356-4226		1. Well Location				Fire # (if avail.)									
Mailing Address 7719 HWY 51 S						Town of MINOCQUA						7719									
City MINOCQUA						State WI		Zip Code 54548				Street Address or Road Name and Number HWY 51 S									
County Oneida		Co. Permit #		Notification #		Completed 10-30-1998		Subdivision Name				Lot #		Block #							
Well Constructor (Business Name) RICHARDSON WELL DRILLING INC				Lic. # 315		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 45.8369 °N -89.7113 °W				Method Code GCD013							
Address HWY 70 W 10681 MINOCQUA WI 54548				Well Plan Approval #		NW SW Section Township Range or Govt Lot # 26 39 N 6 E		2. Well Type New Well				of previous unique well #		constructed in							
Hicap Permanent Well #				Common Well #		Specific Capacity 3.8				Reason for replaced or reconstructed well ?				Construction Type Drilled							
3. Well serves 1 # of						Hicap Well ? No				Private, potable				Hicap Property ? No							
Heat Exchange ___ # of drillholes						Hicap Potable ?				Reason for replaced or reconstructed well ?				Construction Type Drilled							
4. Potential Contamination Sources - ON REVERSE SIDE														5. Drillhole Dimensions and Construction Method		8. Geology					
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		55		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				S SAND Surface 40 Y SAND @ GRAVEL 40 55				26 ft. below ground surface		12 in. above grade					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		26 ft. below ground surface				12 in. above grade							
6		NEW BLK ASTM A53 WELD 18 97 LBS SAWHILL USA				Surface		52		10. Pump Test				Developed ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 30 ft. below surface				Disinfected ? Yes							
5		JOHNSON 10 SLOT				52		55		Pumping at 15 GP M for 2 Hrs.				Capped ? Yes							
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?				Filled & Sealed Well(s) as needed? Yes			
Method														13. Constructor / Supervisory Driller				Lic #		Date Signed	
Method														MHH				10-30-1998		Date Signed	
Method														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		80	Building Overhang		10
			Septic or Holding, or POWTS Tank		60

Comment:

Created On: 01-07-1999

Updated On: 06-30-2020

Review Status: