Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LB440

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: OLSON, KIM	Phone #
Mailing Address: W3213 SCHAEFER RD	
City: BELLEVILLE	State: WI — Zip Code: 53508
County: Green	Co. Permit #	Notification #	Completed: 10-07-1998

1. Well Location

Town of EXETER

Fire # (if avail.)

Street Address or Road Name and Number: W3213 SCHAEFER RD

Subdivision Name	Lot #	Block #
SUGAR RIVER EST	18	

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
NIFFENEGGER WELL @ PUMP INC	6295	

Latitude / Longitude in Decimal Degree (DD): 42.8385 °N -89.5228 °W — Method Code: GCD013

Well Plan Approval #

SW	NW	Section	Township	Range
or Govt Lot #		11	4 N	8 E

Address: 902 2ND ST, MONROE WI 53566

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		3

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8.75	Surface	109
6	109	135

Upper Enlarged Drillhole — Lower Open Bedrock

Yes — Rotary - Mud Circulation .....

Rotary - Air .....

Rotary - Air & Foam .....

Drill-Through Casing Hammer

Reverse Rotary

Cable-tool Bit ____in. dia...

Dual Rotary .....

Temp. Outer Casing ____in. dia

Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		TOPSOIL	Surface	1
T		C		BROWN CLAY	1	7
		Y		SAND @ GRAVEL	7	62
		C	G	BLUE @ BROWN CLAY W GRAVEL	62	100
		G		GRAVEL	100	105
		L	S	SANDY LIMESTONE	105	135

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STD WT ST 280 WALL 18 97# PER FT PL END WELDED JTSSAWHILL A53B ASTM	Surface	109
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

15 ft. below ground surface

10. Pump Test

Pumping level 20 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

42 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
MUD @ CUTTINGS	Surface	109	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
RN		10-08-1998
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	65

Type	Qualifier	Distance
Building Overhang		30
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 11-02-1998 Updated On: 01-21-2020 Review Status: