

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LB440		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A													
Property Owner OLSON, KIM						Phone #		1. Well Location				Fire # (if avail.)											
Mailing Address W3213 SCHAEFER RD						Town of EXETER																	
City BELLEVILLE						State WI		Zip Code 53508				Street Address or Road Name and Number W3213 SCHAEFER RD											
County Green		Co. Permit #		Notification #		Completed 10-07-1998		Subdivision Name SUGAR RIVER EST				Lot # 18		Block #									
Well Constructor (Business Name) NIFFENEGGER WELL @ PUMP INC				Lic. # 6295		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 42.8385 °N -89.5228 °W				Method Code GCD013									
Address 902 2ND ST MONROE WI 53566				Well Plan Approval #		SW NW Section Township Range or Govt Lot # 11 4 N 8 E				2. Well Type New Well													
						Approval Date (mm-dd-yyyy)				of previous unique well # constructed in													
Hicap Permanent Well #		Common Well #		Specific Capacity 3		Reason for replaced or reconstructed well ?																	
3. Well serves 1 # of				Hicap Well ? No		Construction Type Drilled																	
Private, potable				Hicap Property ? No																			
Heat Exchange ___ # of drillholes				Hicap Potable ?																			
4. Potential Contamination Sources - ON REVERSE SIDE																							
5. Drillhole Dimensions and Construction Method												8. Geology											
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)										
8.75 Surface 109			Yes Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						TOPSOIL		Surface		1										
6 109 135									T C		BROWN CLAY		1		7								
									Y		SAND @ GRAVEL		7		62								
									C G		BLUE @ BROWN CLAY W GRAVEL		62		100								
									G		GRAVEL		100		105								
			L S		SANDY LIMESTONE		105		135														
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is							
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		15 ft. below ground surface				42 in. above grade									
6		STD WT ST 280 WALL 18 97# PER FT PL END WELDED JTSSAWHILL A53B ASTM				Surface		109		10. Pump Test				Developed ? Yes									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 20 ft. below surface				Disinfected ? Yes									
										Pumping at 15 GP M for 2 Hrs.				Capped ? Yes									
										Pumping Method ?													
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?											
Method												Filled & Sealed Well(s) as needed?											
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller				Lic #		Date Signed							
MUD @ CUTTINGS				Surface		109		RN						10-08-1998									
								Drill Rig Operator				Lic or Reg #		Date Signed									

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	65	Building Overhang		30
			Septic or Holding, or POWTS Tank		50

Comment:

Created On: 11-02-1998

Updated On: 01-21-2020

Review Status: