Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LE835

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: MATTSON, DOREEN	Phone #
Mailing Address: N8038 CO RD A	
City: HIXTON	State: WI — Zip Code: 54635
County: Jackson	Co. Permit #: — Notification #: — Completed: 01-07-2002
Well Constructor (Business Name): RUSH & SONS WELL DRILLING LLC	Lic. #: 6462 — Facility ID # (Public Wells):
Address: N7570 N ODEEN RD, BLACK RIVER FALLS WI 54615-5818	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 8

1. Well Location

Town of HIXTON				Fire # (if avail.): N8038
Street Address or Road Name and Number: CO RD A				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code:
NW / NE or Govt Lot #:		Section: 27	Township: 22 N	Range: 5 W

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: NEW HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	32

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q S -	SAND, CAVING, TAN	Surface	32

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL #18.97/FT, ASTM A53B IPSCO USA WELDED	Surface	28
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELESCOPE STAINLESS STEEL 10 SLOT	28	32

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 13 ft. below surface
Pumping at 8 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? No
OWNER WILL COMPLY

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR		01-30-2002
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		8	Sewer - Building Sanitary	>	50
			Septic or Holding, or POWTS Tank	>	50

Comment:

Created On: 03-14-2002 Updated On: 03-12-2003 Review Status: