Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LE837

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BRAUNER, BILL		Phone #: (715)333-7005
Mailing Address: N9007 CO RD E		
City: BLACK RIVER FALLS	State: WI	Zip Code: 54615

County	Co. Permit #	Notification #	Completed
Jackson			01-28-2002

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
RUSH & SONS WELL DRILLING LLC	6462	

Address: N7570 N ODEEN RD
BLACK RIVER FALLS WI 54615-5818

Well Plan Approval #:

Approval Date (mm-dd-yyyy):

Hicap Permanent Well #	Common Well #	Specific Capacity
		2

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Fire # (if avail.): N9007

Town of ADAMS

Street Address or Road Name and Number: CO RD E

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.3993 °N	-90.7781 °W			GCD013

NW	SW	Section	Township	Range
or Govt Lot #		8	22 N	3 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
DOG KENNEL

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	34
6	34	50

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 8in. dia... No
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
-	Q	X	-	SAND & CLAY CAVING	Surface	18
I	H	N	-	SANDROCK, HARD, WHITE	18	50

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL #18.97/FT ASTM A53B IPSCO USA WELDED	Surface	34
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
12 ft. below ground surface

10. Pump Test
Pumping level 16 ft. below surface
Pumping at 8 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE, PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
NEAT CEMENT	Surface	34	5.5 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR		01-30-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	100	Sewer - Building Sanitary	>	90
Building Overhang		85	Animal Yard - Include Hutches	>	60
			Septic or Holding, or POWTS Tank	>	75

Comment:

Created On: 03-14-2002 Updated On: 05-01-2020 Review Status: