Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LE839

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: MAJESTIC HOMES			Phone #: (715)284-8399
Mailing Address: W10120 STATE HWY 54			
City: BLACK RIVER FALLS	State: WI	Zip Code: 54615	
County: Jackson	Co. Permit #:	Notification #:	Completed: 01-22-2002

Well Constructor (Business Name): RUSH & SONS WELL DRILLING LLC	Lic. #: 6462	Facility ID # (Public Wells):	
Address: N7570 N ODEEN RD BLACK RIVER FALLS WI 54615-5818		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of GARDEN VALLEY

Fire # (if avail.): W1375

Street Address or Road Name and Number: NW BURNETTE RD

Subdivision Name:	Lot #:	Block #:

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code:

SW SW or Govt Lot #	Section: 28	Township: 23 N	Range: 5 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	32

Upper Enlarged Drillhole / Lower Open Bedrock

Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Yes Cable-tool Bit 6in. dia... No
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q S -	SAND, CAVING, TAN	Surface	32

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL #18.97/FT ASTM A53B IPSCO USA WELDED	Surface	28
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	TELESCOPE STAINLESS STEEL 10 SLOT	28	32

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 12 ft. below surface
Pumping at 8 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR		02-06-2002
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Sewer - Building Sanitary		35
Building Overhang		14	Septic or Holding, or POWTS Tank		52

Comment:

Created On: 03-14-2002 Updated On: 03-14-2002 Review Status: