

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LE840		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner CENTRAL CONSTRUCTION/C FERDINAND						Phone # (715)597-6565		1. Well Location				Fire # (if avail.)									
Mailing Address 12723 DIVISION						Town of SUMNER						Street Address or Road Name and Number									
City OSSEO						State WI		Zip Code 54758				N50461 DURST RD									
County Trempealeau		Co. Permit #		Notification #		Completed 01-31-2002		Subdivision Name				Lot # 22		Block #							
Well Constructor (Business Name) RUSH & SONS WELL DRILLING LLC				Lic. # 6462		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.5747 °N -91.2047 °W				Method Code GCD013							
Address N7570 N ODEEN RD BLACK RIVER FALLS WI 54615-5818				Well Plan Approval #				NW SW		Section 11		Township 24 N		Range 7 W							
				Approval Date (mm-dd-yyyy)				or Govt Lot #													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.5				2. Well Type New Well				of previous unique well #		constructed in					
Reason for replaced or reconstructed well ?				NEW HOME				Construction Type Drilled													
3. Well serves 1 # of Private, potable						Hicap Well ? No															
Heat Exchange ___ # of drillholes						Hicap Property ? No															
						Hicap Potable ?															
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)	
6		Surface		65										T Q S -		SAND, CAVING, TAN		Surface		35	
						Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary								T S N -		SANDROCK, TAN, SOFT		35		46	
						Yes Cable-tool Bit 6in. dia... No Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								T H N -		SANDROCK, TAN, HARD		46		65	
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		18 ft. below ground surface				14 in. above grade							
6		STEEL, #18.97/FT ASTM A53B IPSCO USA WELDED				Surface		46		10. Pump Test Pumping level 34 ft. below surface Pumping at 8 GP M for 4 Hrs. Pumping Method ?				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)													
7. Grout or Other Sealing Material Method														12. Notified Owner of need to fill & seal ? Filled & Sealed Well(s) as needed? NONE							
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement													
				Surface																	
														13. Constructor / Supervisory Driller				Lic #		Date Signed	
														JAR						02-04-2002	
														Drill Rig Operator				Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Sewer - Building Sanitary		35
Building Overhang		25	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 03-14-2002

Updated On: 07-31-2019

Review Status: