Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LE840

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: CENTRAL CONSTRUCTION/C FERDINAND			Phone #: (715)597-6565
Mailing Address: 12723 DIVISION			
City: OSSEO	State: WI	Zip Code: 54758	
County: Trempealeau	Co. Permit #:	Notification #:	Completed: 01-31-2002

Well Constructor (Business Name): RUSH & SONS WELL DRILLING LLC	Lic. #: 6462	Facility ID # (Public Wells):	
Address: N7570 N ODEEN RD BLACK RIVER FALLS WI 54615-5818		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 0.5	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of SUMNER

Fire # (if avail.):

Street Address or Road Name and Number: N50461 DURST RD

Subdivision Name:	Lot #: 22	Block #:

Latitude / Longitude in Decimal Degree (DD): 44.5747 °N -91.2047 °W
Method Code: GCD013

NW SW or Govt Lot #	Section	Township	Range
	11	24 N	7 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	65

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes / No — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
T Q S -	SAND, CAVING, TAN	Surface	35
T S N -	SANDROCK, TAN, SOFT	35	46
T H N -	SANDROCK, TAN, HARD	46	65

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL, #18.97/FT ASTM A53B IPSCO USA WELDED	Surface	46
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
	Surface		

9. Static Water Level
18 ft. below ground surface

10. Pump Test
Pumping level 34 ft. below surface
Pumping at 8 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAR		02-04-2002
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75	Sewer - Building Sanitary		35
Building Overhang		25	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 03-14-2002 Updated On: 07-31-2019 Review Status: