Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LI113

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: REHBERGH, MIKE	Phone #
Mailing Address: PO BOX 414	
City: ELEVA	State: WI — Zip Code: 54738
County: Trempealeau	Co. Permit #	Notification #	Completed: 12-30-1996

1. Well Location

Town of ALBION	Fire # (if avail.): W23255
Street Address or Road Name and Number: ST HWY 10	
Subdivision Name	Lot #	Block #

Well Constructor (Business Name): BERGH CONTRACTOR INC	Lic. #: 151	Facility ID # (Public Wells)	Well Plan Approval #
Address: 943 HARLEM ST ALTOONA WI 54720-1126			Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.1	

Latitude / Longitude in Decimal Degree (DD): 44.55846 °N -91.41241 °W				Method Code: GPS008
NE SE or Govt Lot #		Section: 13	Township: 24 N	Range: 9 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	49

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K I	BLACK DIRT	Surface	1
S	SAND	1	30
Y	SAND @ GRAVEL	30	49

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	953 GRADE BA S36625 K280 BD II 452 40992 SAWHILL	Surface	45
Dia. (in.)	**Screen type, material & slot size**	**From (ft.)**	**To (ft.)**
4	10 SLOT JOHNSON STAINLESS STEEL	45	49

7. Grout or Other Sealing Material
Method

9. Static Water Level
29 ft. below ground surface

10. Pump Test
Pumping level 40 ft. below surface
Pumping at 12 GP M for 5 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJB		
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		75
Building Drain - Sanitary		71
Building Overhang		71

Type	Qualifier	Distance
Foundation Drain to Sewer		71
Sewer - Building Sanitary		71
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 03-18-1997 Updated On: 08-17-2022 Review Status: