Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LI162

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: NUTZMANN, STEVE			Phone #: (715)720-5062
Mailing Address: 1028 DUTCHMAN DR 3			
City: CHIPPEWA FALLS	State: WI	Zip Code: 54729	
County: Chippewa	Co. Permit #: W13729	Notification #:	Completed: 12-31-1996

Well Constructor (Business Name): DANIEL B OLSON	Lic. #: 352	Facility ID # (Public Wells):	
Address: 3188 SUNDET RD EAU CLAIRE WI 54703-0346		Well Plan Approval #:	
		Approval Date (mm-dd-yyyy):	
Hicap Permanent Well #:	Common Well #:	Specific Capacity: 6.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of LAFAYETTE

Fire # (if avail.): 18410

Street Address or Road Name and Number: 18410 67TH AVE N

Subdivision Name: LAKEWOOD MANOR	Lot #: 26	Block #

Latitude / Longitude in Decimal Degree (DD): 44.9403 °N -91.2989 °W				Method Code: GCD013
SE NW or Govt Lot #	Section: 1	Township: 28 N	Range: 8 W	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	47

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND @ GRAVEL	Surface	47

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL NEW BLACK T@C ASTM A53 280 WALL 19 45 LBSPER FT SAWHILL @ IPSCO STEEL	Surface	44
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	COOK STAINLESS 10 SLOT	44	47

7. Grout or Other Sealing Material
Method

9. Static Water Level
33.5 ft. below ground surface

10. Pump Test
Pumping level 35 ft. below surface
Pumping at 10 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
DO		01-01-1997
Drill Rig Operator	Lic or Reg #	Date Signed
KO		12-31-1996

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		70
Building Drain - Sanitary		39

Type	Qualifier	Distance
Building Overhang		13
Sewer - Building Sanitary		53
Septic or Holding, or POWTS Tank		60

Comment:

Created On: 03-05-1997 Updated On: 06-11-2020 Review Status: