

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LI171		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BERGERON, TIM						Phone # (715)288-6044		1. Well Location				Fire # (if avail.)					
Mailing Address 15996 135TH AVE						Town of EAGLE POINT											
City CHIPPEWA FALLS						State WI		Zip Code 54729									
County Chippewa		Co. Permit # W13387		Notification #		Completed 01-28-1997		Subdivision Name				Lot # Block #					
Well Constructor (Business Name) BERGH CONTRACTOR INC				Lic. # 151		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD)				Method Code					
Address 943 HARLEM ST ALTOONA WI 54720-1126				Well Plan Approval #		Approval Date (mm-dd-yyyy)		SE NE Section Township Range		°N °W							
								or Govt Lot # 33 30 N 8 W									
Hicap Permanent Well #		Common Well #		Specific Capacity 0.5		2. Well Type New Well											
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes						Hicap Well ? No		Reason for replaced or reconstructed well ? NEW HOME									
						Hicap Property ? No											
4. Potential Contamination Sources - ON REVERSE SIDE						Hicap Potable ?		Construction Type Drilled									
5. Drillhole Dimensions and Construction Method												8. Geology					
Dia. (in.) From (ft.) To (ft.)			Upper Enlarged Drillhole Lower Open Bedrock Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)						Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.) To (ft.)				
10 Surface 37									C H		CLAY SHALE		Surface 12				
6 37 160									S N H		SHALE SOFT SANDSTONE		12 27				
					S N		SOFT SANDSTONE		27 36								
					N		SANDSTONE		36 160								
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.) To (ft.)		110 ft. below ground surface				16 in. above grade					
6.625		953 GRADE BA536 625 K280 BID II 452 40992 SAWHILLP E				Surface 44		10. Pump Test				Developed ? Yes					
Dia. (in.)		Screen type, material & slot size				From (ft.) To (ft.)		Pumping level 130 ft. below surface				Disinfected ? Yes					
								Pumping at 10 GP M for 6 Hrs.				Capped ? Yes					
								Pumping Method ?									
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?					
Method TREMIE GRAVITY																	
Kind of Sealing Material		From (ft.) To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?											
PORTLAND TYPE 1		Surface 37		17 S													
												13. Constructor / Supervisory Driller		Lic #		Date Signed	
												EJB				01-30-1997	
												Drill Rig Operator		Lic or Reg #		Date Signed	

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)	>	60	Building Overhang	>	10
Building Drain - Sanitary	>	10	Sewer - Building Sanitary	>	10
			Septic or Holding, or POWTS Tank	>	30

Comment:

Created On: 04-18-1997

Updated On: 04-18-1997

Review Status: