Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LI186

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GIESE, ROLAND			Phone #
Mailing Address: 6854 W LOWES CREEK			
City: EAU CLAIRE	State: WI	Zip Code: 54701	
County: Eau Claire	Co. Permit #: W13385	Notification #	Completed: 05-02-1997

Well Constructor (Business Name): BERGH CONTRACTOR INC	Lic. #: 151	Facility ID # (Public Wells)	
Address: 943 HARLEM ST ALTOONA WI 54720-1126		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.4	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of WASHINTON
Street Address or Road Name and Number

Fire # (if avail.)

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): °N °W
Method Code

SE	SW	Section	Township	Range
or Govt Lot #		18	26 N	9 W

2. Well Type New Well
of previous unique well # constructed in 97

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	33
6	33	80

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes Cable-tool Bit 6in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
K		I		BLACK DIRT	Surface	1
		S		SAND	1	5
		H	N	CLAY @ SHALE SAND STONE	5	28
		N		SAND STONE	28	80

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6.625	953 GRADE BA 536 625 @ 280 BID II452 40992 SAWHILL	Surface	33
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material
Method TREMIE GRAVITY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
PORTLAND TYPE 1	Surface	35	12 S

9. Static Water Level
40 ft. below ground surface

10. Pump Test
Pumping level 65 ft. below surface
Pumping at 10 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
14 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
EJB		05-26-1997
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		100
Building Drain - Sanitary	>	10
Building Overhang		10
Foundation Drain to Sewer	>	10
Sewer - Building Sanitary	>	10
Septic or Holding, or POWTS Tank		50

Comment:

Created On: 09-09-1997 Updated On: 09-09-1997 Review Status: