Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LI202

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BOWE, GERALD	Phone #: (715)835-7465
Mailing Address: 6683 HWY 53	
City: EAU CLAIRE	State: WI — Zip Code: 54701
County: Eau Claire	Co. Permit #: W13383 — Notification # — Completed: 02-19-1997
Well Constructor (Business Name): DANIEL B OLSON	Lic. #: 352 — Facility ID # (Public Wells)
Address: 3188 SUNDET RD, EAU CLAIRE WI 54703-0346	Well Plan Approval # — Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 1.5

1. Well Location

Town of WASHINGTON

Fire # (if avail.)

Street Address or Road Name and Number: 9290 HWY 53

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)	Method Code
44.6977 °N -91.3503 °W	GCD013

SE or Govt Lot #	SE	Section	Township	Range
		28	26 N	8 W

2. Well Type Replacement

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?: POINT IN BASEMENT

Construction Type: Drilled

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
10	Surface	12
6	12	58

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Yes — Cable-tool Bit 10in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		C		CLAY	Surface	12
		S		SAND	12	23
		X		SAND @ CLAY	23	34
	N	S		FINE SAND	34	54
	A	S		COARSE SAND	54	58

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	STEEL T @ C NEW BLACK 19 45 LBS PER FT 280 WALLASTM A53 LTV @ SAWHILL STEEL	Surface	55
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	3 FT 10 SLOT COOK SCREEN	55	58

9. Static Water Level

28 ft. below ground surface

10. Pump Test

Pumping level 38 ft. below surface

Pumping at 15 GP M for 2 Hrs.

Pumping Method ?

11. Well Is

18 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CLAY SLURRY	Surface	12	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
DBO		02-19-1997
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
KDO		02-19-1997

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		82
Building Drain - Sanitary		34

Type	Qualifier	Distance
Building Overhang		10
Sewer - Building Sanitary		38
Septic or Holding, or POWTS Tank		45

Comment:

Created On: 03-21-1997 Updated On: 08-01-2019 Review Status: