

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LI202		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A											
Property Owner BOWE, GERALD						Phone # (715)835-7465		1. Well Location				Fire # (if avail.)									
Mailing Address 6683 HWY 53						Town of WASHINGTON															
City EAU CLAIRE						State WI		Zip Code 54701													
County Eau Claire		Co. Permit # W13383		Notification #		Completed 02-19-1997		Subdivision Name				Lot # Block #									
Well Constructor (Business Name) DANIEL B OLSON				Lic. # 352		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) 44.6977 °N -91.3503 °W				Method Code GCD013									
Address 3188 SUNDET RD EAU CLAIRE WI 54703-0346				Well Plan Approval #		SE SE Section Township Range or Govt Lot # 28 26 N 8 W		2. Well Type Replacement of previous unique well # constructed in Reason for replaced or reconstructed well ? POINT IN BASEMENT													
				Approval Date (mm-dd-yyyy)																	
Hicap Permanent Well #		Common Well #		Specific Capacity 1.5																	
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?				Construction Type Drilled													
4. Potential Contamination Sources - ON REVERSE SIDE																					
5. Drillhole Dimensions and Construction Method														8. Geology							
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)					
10		Surface		12		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary <u>Yes</u> Cable-tool Bit 10in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				C		CLAY		Surface		12					
6		12		58						S		SAND		12		23					
										X		SAND @ CLAY		23		34					
										N S		FINE SAND		34		54					
										A S		COARSE SAND		54		58					
6. Casing, Liner, Screen														9. Static Water Level				11. Well Is			
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		28 ft. below ground surface				18 in. above grade							
6		STEEL T @ C NEW BLACK 19 45 LBS PER FT 280 WALLASTM A53 LTV @ SAWHILL STEEL				Surface		55		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes							
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 38 ft. below surface Pumping at 15 GP M for 2 Hrs. Pumping Method ?											
5		3 FT 10 SLOT COOK SCREEN				55		58													
7. Grout or Other Sealing Material														12. Notified Owner of need to fill & seal ?							
Method																					
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		Filled & Sealed Well(s) as needed?				Yes							
CLAY SLURRY				Surface		12															
13. Constructor / Supervisory Driller								Lic #		Date Signed											
DBO										02-19-1997											
Drill Rig Operator								Lic or Reg #		Date Signed											
KDO										02-19-1997											

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		82	Building Overhang		10
Building Drain - Sanitary		34	Sewer - Building Sanitary		38
			Septic or Holding, or POWTS Tank		45

Comment:

Created On: 03-21-1997

Updated On: 08-01-2019

Review Status: