Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LJ399

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: HOY, JOE			Phone #
Mailing Address: W9423 22ND ST			
City: NECEDAH	State: WI	Zip Code: 54646	
County: Juneau	Co. Permit #	Notification #	Completed: 11-07-1997

Well Constructor (Business Name): RAYMOND J LUDWIG	Lic. #: 316	Facility ID # (Public Wells)	
Address: N7644 10TH AVE NEW LISBON WI 53950-0052		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location

Town of CUTLER				Fire # (if avail.): W9423
Street Address or Road Name and Number: W9423 22ND ST				
Subdivision Name			Lot #	Block #
Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code
NW NE or Govt Lot #	Section: 22	Township: 18 N	Range: 2 E	

2. Well Type Replacement
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
OLD POINT PLUGGED

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	109

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	34
R		C		RED CLAY	34	47
		S		SAND	47	74
Y		N		SANDSTONE YELLOW	71	109

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLACK STEEL PE ASTM A53 18976BS FT 280 WALL SAWHIL	Surface	100
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
5	SS 10 SLOT	100	109

7. Grout or Other Sealing Material
Method

9. Static Water Level
16 ft. below ground surface

10. Pump Test
Pumping level 50 ft. below surface
Pumping at 1 GP M for 6 Hrs.
Pumping Method ?

11. Well Is
26 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
OWNER TO DO

13. Constructor / Supervisory Driller	Lic #	Date Signed
RL		11-10-1997
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		73	Sewer - Building Sanitary		27
Building Overhang		4	Septic or Holding, or POWTS Tank		58

Comment:

Created On: 04-28-1998 Updated On: 10-15-2026 Review Status: