Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LJ718

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner	HOLTHOUS, LLOYD
Phone #	
Mailing Address	2534 BAINBRIDGE ST
City	LA CROSSE
State	WI
Zip Code	54603

County	Co. Permit #	Notification #	Completed
La Crosse	W15012		03-18-1998

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
DUANE FRAUENKRON	638	

Address RT 1 BOX 45
HOKAH MN 55941-9705

Well Plan Approval #

Approval Date (mm-dd-yyyy)

Hicap Permanent Well #	Common Well #	Specific Capacity

3. Well serves 1 # of HOME
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of CAMPBELL

Fire # (if avail.)

Street Address or Road Name and Number
2616 THOMAS ST

Subdivision Name	Lot #	Block #
BAYVIEW ADD	2	5

Latitude / Longitude in Decimal Degree (DD)	Method Code
43.8674 °N -91.2718 °W	GCD013

NE NE or Govt Lot #	Section	Township	Range
	13	16 N	8 W

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?

Construction Type Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
4	Surface	60

Upper Enlarged Drillhole
Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit 4in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
Y	SAND GRAVEL	Surface	60

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
4	ASTM A53 PE SAWHILL 10 79	Surface	57
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
4	STAINLESS STEEL	57	60

7. Grout or Other Sealing Material
Method

9. Static Water Level
27 ft. below ground surface

10. Pump Test
Pumping level 27 ft. below surface
Pumping at 12 GP M for 3 Hrs.
Pumping Method ?

11. Well Is
17 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?
NEW CONST

13. Constructor / Supervisory Driller	Lic #	Date Signed
DEF		05-12-1998
Drill Rig Operator	Lic or Reg #	Date Signed
DEF		

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		31	Collector Sewer - San or Storm		61
Building Overhang		7	Sewer - Building Sanitary		28

Comment:

Created On: 09-01-1998 Updated On: 04-30-2020 Review Status: