Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LK141

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GIBSON, DAN			Phone #: (414)941-1974
Mailing Address: 2305 LANCE DR			
City: LAKE GENEVA	State: WI	Zip Code: 53157	
County: Walworth	Co. Permit #: W33862	Notification #	Completed: 01-27-1997

1. Well Location

Town of LAKE GENEVA

Fire # (if avail.)

Street Address or Road Name and Number: ROSEBUD HIGHLANDS

Subdivision Name	Lot #	Block #
ROSEBUD HIGHLANDS	3	

Well Constructor (Business Name)	Lic. #	Facility ID # (Public Wells)
LOUIS G SIEVERT	475	

Latitude / Longitude in Decimal Degree (DD): °N °W

Method Code

Well Plan Approval #

	NE	NW	Section	Township	Range
or Govt Lot #	025	25		2 N	17 E

Address: 38827 90TH ST
BURLINGTON WI 53105-8513

Approval Date (mm-dd-yyyy)

2. Well Type New Well

of previous unique well # constructed in

Hicap Permanent Well #	Common Well #	Specific Capacity
		0.5

Reason for replaced or reconstructed well ?

3. Well serves 1 # of

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
6	Surface	202

Upper Enlarged Drillhole / Lower Open Bedrock

- Rotary - Mud Circulation .....
- Yes — Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
- Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		Y	C	SAND GRAVEL CLAY	Surface	20
		Y		SAND GRAVEL	20	70
		C		CLAY	70	120
		Y		SAND GRAVEL	120	180
		C		CLAY	200	202

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	BLK PE R D 18 97 LBS A53 SAWHILL USA	Surface	202
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level

140 ft. below ground surface

10. Pump Test

Pumping level 160 ft. below surface

Pumping at 10 GP M for 24 Hrs.

Pumping Method ?

11. Well Is

12 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method POURED WHEN DRIVING

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
GRADULED @ BENTINITE	Surface	201	3 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
LGS		02-03-1997
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
RJ		02-03-1997

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Drain - Sanitary		30	Foundation Drain to Clearwater	>	25
Building Overhang		25	Sewer - Building Sanitary		30
			Septic or Holding, or POWTS Tank		35

Comment:

Created On: 03-18-1997 Updated On: 03-18-1997 Review Status: