Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LK834

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: PETERSON, ROBERT			Phone #
Mailing Address: W5803 ROCK RD			
City: BLACK CREEK	State: WI	Zip Code: 54106	
County: Outagamie	Co. Permit #	Notification #	Completed: 01-24-1997

Well Constructor (Business Name): RED WILLEMS	Lic. #: 451	Facility ID # (Public Wells)	
Address: 7962 ST PATS CHURCH GREENLEAF WI 54126-9611		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 1.7	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of CENTER

Fire # (if avail.)

Street Address or Road Name and Number: W5803 ROCK RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD)				Method Code
44.3677 °N	-88.4835 °W			GCD013
NW SE or Govt Lot #	Section: 19	Township: 22 N	Range: 17 E	

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	63
6	63	102

Upper Enlarged Drillhole / Lower Open Bedrock

Yes — Rotary - Air .....
Rotary - Mud Circulation .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes	Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
X	SAND @ CLAY	Surface	5
L	LIMESTONE	5	53
N	SANDSTONE	53	102

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53 GR B SAWHILL TUBULAR WELDED JOINT WT18 97 PER FT	Surface	63
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
40 ft. below ground surface

10. Pump Test
Pumping level 70 ft. below surface
Pumping at 50 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method TREMIE PIPE PUMPED

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	63	10 S

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJW		02-07-1997
Drill Rig Operator	Lic or Reg #	Date Signed
TW		02-07-1997

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 06-24-1997 Updated On: 11-20-2019 Review Status: