

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LK834		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A															
Property Owner PETERSON, ROBERT						Phone #		1. Well Location				Fire # (if avail.)													
Mailing Address W5803 ROCK RD						Town of CENTER																			
City BLACK CREEK						State WI		Zip Code 54106				Street Address or Road Name and Number W5803 ROCK RD													
County Outagamie		Co. Permit #		Notification #		Completed 01-24-1997		Subdivision Name				Lot # Block #													
Well Constructor (Business Name) RED WILLEMS				Lic. # 451		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD) 44.3677 °N -88.4835 °W				Method Code GCD013											
Address 7962 ST PATS CHURCH GREENLEAF WI 54126-9611				Well Plan Approval #		NW SE Section Township Range or Govt Lot # 19 22 N 17 E				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? NEW HOME															
						Approval Date (mm-dd-yyyy)																			
Hicap Permanent Well #		Common Well #		Specific Capacity 1.7																					
3. Well serves 1 # of Private, potable Heat Exchange ___ # of drillholes				Hicap Well ? No Hicap Property ? No Hicap Potable ?		Construction Type Drilled																			
4. Potential Contamination Sources - ON REVERSE SIDE																									
5. Drillhole Dimensions and Construction Method												8. Geology													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole		Lower Open Bedrock		Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...		From (ft.)		To (ft.)									
8		Surface		63		Rotary - Mud Circulation <u>Yes</u> Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				X		SAND @ CLAY		Surface		5									
6		63		L						LIMESTONE		5		53											
				N						SANDSTONE		53		102											
6. Casing, Liner, Screen												9. Static Water Level				11. Well Is									
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)		40 ft. below ground surface				12 in. above grade											
6		ASTM A53 GR B SAWHILL TUBULAR WELDED JOINT WT18 97 PER FT				Surface		63		10. Pump Test				Developed ? Yes Disinfected ? Yes Capped ? Yes											
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)		Pumping level 70 ft. below surface Pumping at 50 GP M for 4 Hrs. Pumping Method ?															
7. Grout or Other Sealing Material												12. Notified Owner of need to fill & seal ?													
Method TREMIE PIPE PUMPED												Filled & Sealed Well(s) as needed?													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement		13. Constructor / Supervisory Driller										Lic #		Date Signed			
CEMENT				Surface		63		10 S		LJW												02-07-1997			
												Drill Rig Operator				Lic or Reg #		Date Signed							
												TW						02-07-1997							

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		15	Septic or Holding, or POWTS Tank		80

Comment:

Created On: 06-24-1997

Updated On: 11-20-2019

Review Status: