Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LK837

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: GUAY, DAVE			Phone #
Mailing Address: N 6657 HARRISON RD			
City: HILBERT	State: WI	Zip Code: 54129	
County: Calumet	Co. Permit #	Notification #	Completed: 02-03-1997

Well Constructor (Business Name): RED WILLEMS	Lic. #: 451	Facility ID # (Public Wells)	
Address: 7962 ST PATS CHURCH GREENLEAF WI 54126-9611		Well Plan Approval #	
		Approval Date (mm-dd-yyyy)	
Hicap Permanent Well #	Common Well #	Specific Capacity: 0.2	

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes

Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

1. Well Location
Town of HARRISON

Fire # (if avail.)

Street Address or Road Name and Number: N6657 HARRISON RD

Subdivision Name	Lot #	Block #

Latitude / Longitude in Decimal Degree (DD): 44.1295 °N -88.3162 °W
Method Code: GCD013

SE SW or Govt Lot #	Section: 11	Township: 19 N	Range: 18 E

2. Well Type New Well
of previous unique well # constructed in

Reason for replaced or reconstructed well ?
NEW HOME

Construction Type: Drilled

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	120
6	120	347

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Yes Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		X		SAND @ CLAY	Surface	5
	S	H		SOFT SHALE	5	119
		H		SHALE ROCK	119	142
		L		LIMESTONE	142	341
		N		SANDSTONE	341	347

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A5O GRB SAWHILL TUBULAR WELDED JT WT 1897FT	Surface	120
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

7. Grout or Other Sealing Material

Method PRESSURE GROUT

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
CEMENT	Surface	120	16 S

9. Static Water Level
80 ft. below ground surface

10. Pump Test
Pumping level 220 ft. below surface
Pumping at 30 GP M for 4 Hrs.
Pumping Method ?

11. Well Is
12 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

13. Constructor / Supervisory Driller	Lic #	Date Signed
LJW		02-27-1997
Drill Rig Operator	**Lic or Reg #**	**Date Signed**
TW		02-27-1997

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		13	Septic or Holding, or POWTS Tank		45

Comment:

Created On: 03-17-1998 Updated On: 08-13-2019 Review Status: