

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LL504		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A				
Property Owner KINCAID, CORY						Phone # (715)839-9068		1. Well Location				Fire # (if avail.)		
Mailing Address 4704 SPEROS						Town of SEYMOUR								
City EAU CLAIRE						State WI		Zip Code 54701				Street Address or Road Name and Number WOODTRAIL		
County Eau Claire		Co. Permit # W13363		Notification #		Completed 12-15-1996		Subdivision Name WOODLAND TRAILS			Lot # 11		Block #	
Well Constructor (Business Name) WATER WELL SPECIALISTS				Lic. # 6070		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W			Method Code			
Address 3701 ROBIN RD EAU CLAIRE WI 54703				Well Plan Approval #		SE SE		Section 12		Township 27 N		Range 9 W		
Approval Date (mm-dd-yyyy)				Hicap Permanent Well #		Common Well #		Specific Capacity 0.8		2. Well Type New Well				
Hicap Property ? No				Hicap Potable ?		Reason for replaced or reconstructed well ?								
Heat Exchange ___ # of drillholes				Hicap Well ? No		Construction Type Drilled								
3. Well serves # of ONE Private, potable														
4. Potential Contamination Sources - ON REVERSE SIDE														
5. Drillhole Dimensions and Construction Method														
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock				
8		Surface		10		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)								
6		10		135.7										
8. Geology														
Geology Codes		Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)						
T		I		S		LT TOPSOIL				Surface		0.5		
N		S		S		MDM BRN SAND				0.5		78		
G		C		S		MDM BRN SAND W FINE FINES				78		105		
G		U		S		SAND GRAY CLAY WOOD BARK LEAVES				105		117		
G		S		G		GRAY MUD W SAND				117		126.5		
G		S		G		GRAY SAND W STONES				126.5		135.7		
6. Casing, Liner, Screen														
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)						
6		SAWHILL ASTMA53 1897 LB PE DRIVE SHOE 5 IN X 6 INPACKER				Surface		131.8						
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)						
6		CONT WRAP SS 015 IN				131.3		135.7						
7. Grout or Other Sealing Material														
Method MOUNDED IN STARTER														
Kind of Sealing Material		From (ft.)		To (ft.)		# Sacks Cement								
BENTONITE GRANU		Surface		0										
9. Static Water Level														
50 ft. below ground surface														
10. Pump Test														
Pumping level 66 ft. below surface														
Pumping at 12 GP M for 4 Hrs.														
Pumping Method ?														
11. Well Is														
16 in. above grade														
Developed ? Yes														
Disinfected ? Yes														
Capped ? Yes														
12. Notified Owner of need to fill & seal ?														
Filled & Sealed Well(s) as needed? NONE														
13. Constructor / Supervisory Driller														
Lic #		Date Signed												
JAW		12-22-1996												
Drill Rig Operator		Lic or Reg #		Date Signed										

4a. Potential Contamination Sources

Is the well located in floodplain ?

Type	Qualifier	Distance	Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		126	Building Overhang		57
Building Drain - Sanitary		80	Sewer - Building Sanitary		80
			Septic or Holding, or POWTS Tank		90

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Separation Distance Variance	11/04/1996	< REQUIRED 250' FROM A SALVAGE YARD

Created On: 03-03-1997

Updated On: 03-03-1997

Review Status: