Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LL504

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: KINCAID, CORY	Phone #: (715)839-9068
Mailing Address: 4704 SPEROS	
City: EAU CLAIRE	State: WI — Zip Code: 54701
County: Eau Claire	Co. Permit #: W13363 — Notification # — Completed: 12-15-1996
Well Constructor (Business Name): WATER WELL SPECIALISTS	Lic. #: 6070 — Facility ID # (Public Wells)
Address: 3701 ROBIN RD, EAU CLAIRE WI 54703	Well Plan Approval # — Approval Date (mm-dd-yyyy)
Hicap Permanent Well #	Common Well # — Specific Capacity: 0.8

1. Well Location

Fire # (if avail.)

Town of SEYMOUR

Street Address or Road Name and Number: WOODTRAIL

Subdivision Name	Lot #	Block #
WOODLAND TRAILS	11	

Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code

SE or Govt Lot #	SE	Section: 12	Township: 27 N	Range: 9 W

2. Well Type New Well

of previous unique well # — constructed in

Reason for replaced or reconstructed well ?

Construction Type: Drilled

3. Well serves # of ONE

Private,potable

Heat Exchange____# of drillholes

Hicap Well ? No

Hicap Property ? No

Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	10
6	10	135.7

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		I		LT TOPSOIL	Surface	0.5
T		S		MDM BRN SAND	0.5	78
	N	S		MDM BRN SAND W FINE FINES	78	105
G		C	S	SAND GRAY CLAY WOOD BARK LEAVES	105	117
G		U	S	GRAY MUD W SAND	117	126.5
G		S	G	GRAY SAND W STONES	126.5	135.7

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL ASTMA53 1897 LB PE DRIVE SHOE 5 IN X 6 INPACKER	Surface	131.8
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	CONT WRAP SS 015 IN	131.3	135.7

9. Static Water Level

50 ft. below ground surface

10. Pump Test

Pumping level 66 ft. below surface

Pumping at 12 GP M for 4 Hrs.

Pumping Method ?

11. Well Is

16 in. above grade

Developed ? Yes

Disinfected ? Yes

Capped ? Yes

7. Grout or Other Sealing Material

Method MOUNDED IN STARTER

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GRANU	Surface	0	

12. Notified Owner of need to fill & seal ?

Filled & Sealed Well(s) as needed?

NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAW		12-22-1996
Drill Rig Operator	**Lic or Reg #**	**Date Signed**

4a. Potential Contamination Sources Is the well located in floodplain ?

Type	Qualifier	Distance
POWTS dispersal component (soil absorption unit or mound)		126
Building Drain - Sanitary		80

Type	Qualifier	Distance
Building Overhang		57
Sewer - Building Sanitary		80
Septic or Holding, or POWTS Tank		90

Comment:

Variance ID	Variance or Exception Type	Date	Reason
	Separation Distance Variance	11/04/1996	< REQUIRED 250' FROM A SALVAGE YARD

Created On: 03-03-1997 Updated On: 03-03-1997 Review Status: