Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LL511

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707

Form 3300-077A

Property Owner: BREMNESS, TOM	Phone #: (715)289-4678
Mailing Address: 228 E OAK ST	
City: CADOTT	State: WI — Zip Code: 54727
County: Chippewa	Co. Permit #: W13503 — Notification #: — Completed: 12-23-1996
Well Constructor (Business Name): WATER WELL SPECIALISTS	Lic. #: 6070 — Facility ID # (Public Wells):
Address: 3701 ROBIN RD EAU CLAIRE WI 54703	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.2

1. Well Location

Town of SIGEL				Fire # (if avail.):
Street Address or Road Name and Number: HWY 27				
Subdivision Name:		Lot #:		Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W				Method Code:
NW SW or Govt Lot #:	Section: 29	Township: 28 N	Range: 6 W	

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: FUTURE CONSTRUCTION
Construction Type: Drilled

3. Well serves # of ONE
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	10
6	10	55.5

Upper Enlarged Drillhole — Lower Open Bedrock

- Rotary - Mud Circulation .....
- Rotary - Air .....
- Rotary - Air & Foam .....
- Drill-Through Casing Hammer
- Reverse Rotary
- Cable-tool Bit ____in. dia...
- Dual Rotary .....
- Temp. Outer Casing ____in. dia
  - Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		S		SAND	Surface	8
		Y		SAND GRAVEL	8	12
		Z		GRAVEL CLAY	12	33
		Z	G	GRAVEL CLAY W COBBLES	33	52
	H	Q		MILD HARD GRANITE	52	55.5

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	SAWHILL ASTM A53 18 97 LB P E DRIVE SHOE	Surface	53.8
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)

9. Static Water Level
10 ft. below ground surface

10. Pump Test
Pumping level 30 ft. below surface
Pumping at 3 GP M for 2 Hrs.
Pumping Method ?

11. Well Is
16 in. _____ grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MOUNDED IN STARTER

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
BENTONITE GRANULAR	Surface	0	

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed?
NONE

13. Constructor / Supervisory Driller	Lic #	Date Signed
JAW		12-23-1996
Drill Rig Operator	Lic or Reg #	Date Signed

4a. Potential Contamination Sources Is the well located in floodplain ? No

Comment:

Created On: 03-21-1997 Updated On: 03-21-1997 Review Status: