

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LL511		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A							
Property Owner BREMNESS, TOM						Phone # (715)289-4678		1. Well Location				Fire # (if avail.)					
Mailing Address 228 E OAK ST						Town of SIGEL						Street Address or Road Name and Number HWY 27					
City CADOTT				State WI		Zip Code 54727											
County Chippewa		Co. Permit # W13503		Notification #		Completed 12-23-1996		Subdivision Name				Lot #		Block #			
Well Constructor (Business Name) WATER WELL SPECIALISTS				Lic. # 6070		Facility ID # (Public Wells)				Latitude / Longitude in Decimal Degree (DD)				Method Code			
Address 3701 ROBIN RD EAU CLAIRE WI 54703				Well Plan Approval #				°N		°W		NW SW Section Township Range or Govt Lot # 29 28 N 6 W					
				Approval Date (mm-dd-yyyy)													
Hicap Permanent Well #				Common Well #		Specific Capacity 0.2				2. Well Type New Well of previous unique well # constructed in Reason for replaced or reconstructed well ? FUTURE CONSTRUCTION Construction Type Drilled							
3. Well serves # of ONE				Hicap Well ? No													
Private, potable				Hicap Property ? No													
Heat Exchange ___ # of drillholes				Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE																	
5. Drillhole Dimensions and Construction Method																	
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock							
8		Surface		10		Rotary - Mud Circulation Rotary - Air Rotary - Air & Foam Drill-Through Casing Hammer Reverse Rotary Cable-tool Bit ___ in. dia... Dual Rotary Temp. Outer Casing ___ in. dia Removed? ___ depth ft. (If NO explain on back side)				6				10		55.5	
8. Geology																	
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)							
S				SAND				Surface		8							
Y				SAND GRAVEL				8		12							
Z				GRAVEL CLAY				12		33							
Z G				GRAVEL CLAY W COBBLES				33		52							
H Q				MILD HARD GRANITE				52		55.5							
6. Casing, Liner, Screen																	
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)									
6		SAWHILL ASTM A53 18 97 LB P E DRIVE SHOE				Surface		53.8									
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)									
6		SAWHILL ASTM A53 18 97 LB P E DRIVE SHOE				Surface		53.8									
7. Grout or Other Sealing Material																	
Method MOUNDED IN STARTER																	
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement									
BENTONITE GRANULAR				Surface		0		0									
9. Static Water Level																	
10 ft. below ground surface																	
10. Pump Test																	
Pumping level 30 ft. below surface																	
Pumping at 3 GP M for 2 Hrs.																	
Pumping Method ?																	
11. Well Is																	
16 in. _____ grade																	
Developed ? Yes																	
Disinfected ? Yes																	
Capped ? Yes																	
12. Notified Owner of need to fill & seal ?																	
Filled & Sealed Well(s) as needed? NONE																	
13. Constructor / Supervisory Driller																	
Lic #								Date Signed									
JAW								12-23-1996									
Drill Rig Operator								Lic or Reg #									
Date Signed								Date Signed									

4a. Potential Contamination Sources

Is the well located in floodplain ? No

Comment:

Created On: 03-21-1997

Updated On: 03-21-1997

Review Status: