Well Construction Report
WISCONSIN UNIQUE WELL NUMBER LT080

Drinking Water and Groundwater - DG/5
Department of Natural Resources, Box 7921
Madison WI 53707
Form 3300-077A

Property Owner: BICOYO, VICTOR	Phone #: (715)336-3028
Mailing Address: PO BOX 273	
City: GOODMAN	State: WI — Zip Code: 54125
County: Marinette	Co. Permit #: — Notification #: — Completed: 03-05-1997
Well Constructor (Business Name): MAURICE JOHNSON	Lic. #: 664 — Facility ID # (Public Wells):
Address: N19382 CO O, PEMBINE WI 54156-9801	Well Plan Approval #: — Approval Date (mm-dd-yyyy):
Hicap Permanent Well #:	Common Well #: — Specific Capacity: 0.7

1. Well Location
Town of GOODMAN
Fire # (if avail.):
Street Address or Road Name and Number: S HILBERT DR
Subdivision Name: — Lot #: — Block #:
Latitude / Longitude in Decimal Degree (DD): °N °W — Method Code:
SE NW or Govt Lot #: — Section: 8 — Township: 37 N — Range: 17 E

2. Well Type New Well
of previous unique well #: — constructed in:
Reason for replaced or reconstructed well ?: NEW HOME
Construction Type: Drilled

3. Well serves 1 # of
Private,potable
Heat Exchange____# of drillholes
Hicap Well ? No
Hicap Property ? No
Hicap Potable ?

4. Potential Contamination Sources - ON REVERSE SIDE

5. Drillhole Dimensions and Construction Method

Dia. (in.)	From (ft.)	To (ft.)
8	Surface	140
6	140	180

Upper Enlarged Drillhole — Lower Open Bedrock

Yes Rotary - Mud Circulation .....
Rotary - Air .....
Rotary - Air & Foam .....
Drill-Through Casing Hammer
Reverse Rotary
Cable-tool Bit ____in. dia...
Dual Rotary .....
Temp. Outer Casing ____in. dia
Removed? ____depth ft. (If NO explain on back side)

8. Geology

Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...	From (ft.)	To (ft.)
		G	C	CLAYISH GRAVEL BOULDERS	Surface	140
	M	Y		MEDIUM GRAVEL SAND	140	180

6. Casing, Liner, Screen

Dia. (in.)	Material, Weight, Specification Manufacturer & Method of Assembly	From (ft.)	To (ft.)
6	ASTM A53B SAWHILL 280 W 18 97 LBS PER FT WELDED	Surface	177
Dia. (in.)	Screen type, material & slot size	From (ft.)	To (ft.)
6	3 FT NO 15 SS TELESCOPING	177	180

9. Static Water Level
130 ft. below ground surface

10. Pump Test
Pumping level 160 ft. below surface
Pumping at 20 GP M for 1 Hrs.
Pumping Method ?

11. Well Is
18 in. above grade
Developed ? Yes
Disinfected ? Yes
Capped ? Yes

7. Grout or Other Sealing Material
Method MID ROTARY

Kind of Sealing Material	From (ft.)	To (ft.)	# Sacks Cement
DRILL SLURRY CUTTINGS	Surface	140	4 S

12. Notified Owner of need to fill & seal ?
Filled & Sealed Well(s) as needed? Yes

13. Constructor / Supervisory Driller	Lic #	Date Signed
MJ		05-05-1997
Drill Rig Operator	Lic or Reg #	Date Signed
DJM		05-04-1997

4a. Potential Contamination Sources Is the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		60	Privy		62

Comment:

Created On: 07-08-1997 Updated On: 07-08-1997 Review Status: