

Well Construction Report WISCONSIN UNIQUE WELL NUMBER				LT080		Drinking Water and Groundwater - DG/5 Department of Natural Resources, Box 7921 Madison WI 53707				Form 3300-077A			
Property Owner BICOYO, VICTOR						Phone # (715)336-3028		1. Well Location				Fire # (if avail.)	
Mailing Address PO BOX 273						Town of GOODMAN							
City GOODMAN						State WI		Zip Code 54125					
County Marinette		Co. Permit #		Notification #		Completed 03-05-1997		Subdivision Name				Lot # Block #	
Well Constructor (Business Name) MAURICE JOHNSON				Lic. # 664		Facility ID # (Public Wells)		Latitude / Longitude in Decimal Degree (DD) °N °W				Method Code	
Address N19382 CO O PEMBINE WI 54156-9801				Well Plan Approval #		SE NW Section Township Range or Govt Lot # 8 37 N 17 E		2. Well Type New Well				of previous unique well # constructed in	
Hicap Permanent Well #		Common Well #		Specific Capacity 0.7		Reason for replaced or reconstructed well ? NEW HOME							
3. Well serves 1 # of Private, potable				Hicap Well ? No		Construction Type Drilled							
Heat Exchange ___ # of drillholes				Hicap Property ? No									
Hicap Potable ?													
4. Potential Contamination Sources - ON REVERSE SIDE													
5. Drillhole Dimensions and Construction Method													
Dia. (in.)		From (ft.)		To (ft.)		Upper Enlarged Drillhole				Lower Open Bedrock			
8		Surface		140		Yes Rotary - Mud Circulation							
6		140		180		Rotary - Air							
						Rotary - Air & Foam							
						Drill-Through Casing Hammer							
						Reverse Rotary							
						Cable-tool Bit ___ in. dia...							
						Dual Rotary							
						Temp. Outer Casing ___ in. dia							
						Removed? ___ depth ft. (If NO explain on back side)							
6. Casing, Liner, Screen													
Dia. (in.)		Material, Weight, Specification Manufacturer & Method of Assembly				From (ft.)		To (ft.)					
6		ASTM A53B SAWHILL 280 W 18 97 LBS PER FT WELDED				Surface		177					
Dia. (in.)		Screen type, material & slot size				From (ft.)		To (ft.)					
6		3 FT NO 15 SS TELESCOPING				177		180					
7. Grout or Other Sealing Material													
Method MID ROTARY													
Kind of Sealing Material				From (ft.)		To (ft.)		# Sacks Cement					
DRILL SLURRY CUTTINGS				Surface		140		4 S					
8. Geology													
Geology Codes				Type, Caving/Noncaving, Color, Hardness, etc...				From (ft.)		To (ft.)			
G C				CLAYISH GRAVEL BOULDERS				Surface		140			
M Y				MEDIUM GRAVEL SAND				140		180			
9. Static Water Level													
130 ft. below ground surface													
10. Pump Test													
Pumping level 160 ft. below surface													
Pumping at 20 GP M for 1 Hrs.													
Pumping Method ?													
11. Well Is													
18 in. above grade													
Developed ? Yes													
Disinfected ? Yes													
Capped ? Yes													
12. Notified Owner of need to fill & seal ?													
Filled & Sealed Well(s) as needed? Yes													
13. Constructor / Supervisory Driller						Lic #		Date Signed					
MJ								05-05-1997					
Drill Rig Operator						Lic or Reg #		Date Signed					
DJM								05-04-1997					

4a. Potential Contamination SourcesIs the well located in floodplain ? No

Type	Qualifier	Distance	Type	Qualifier	Distance
Building Overhang		60	Privy		62

Comment:

Created On: 07-08-1997

Updated On: 07-08-1997

Review Status: